Online Comment

Application	H16-0256-17
Location	11a Spalding Common Spalding PE11 3AS
Proposal	Residential development comprising 5 two-bedroom dwellings - re-submission of H16-1198-16

Name	J Reith
Address	Environmental Health Technician Safety and Environment

Date Submitted	05-04-17
For/Against	Comments

A previous site investigation for this property concluded that there is a 'moderate' risk posed by ground gas at the site. Therefore
mitigation measures are required in the proposed properties to protect the end users. I request parts 3 and 4 of the contaminated land condition for this application.