

Online Comment

Application H16-0309-25
Location Millfield House Spalding Common Spalding PE11 3AU
Proposal Details of verification report (Condition 5 of H16-0134-23)

Name Oliver Abrams
Address SHDC Environmental Protection Officer

Date Submitted 14-05-25
For/Against Comments

I have reviewed GeoDyne Limited, Ground Gas Verification Plan, Project No: D44007, Dated 3rd May 2024 for proposed ground gas measures. I am in general agreement with these measures.

I have reviewed MEC Environmental Ltd, Gas Membrane Installation Validation Report, V1 Dated 07/10/24 for Millfield Phase 2. I am in agreement with its findings and gas protection measures have been installed in accordance with the ground gas verification plan (Project no: D44007). I therefore can recommend that condition 5 is fully discharged.