Online Comment

Application	H16-0373-26
Location	3 Holbeach Road Spalding PE11 2HJ
Proposal	Change of use of the first floor and part of the ground floor from commercial, business & service use (Use Class E) to one dwelling house (Use Class C3)

Name	Diane Gordon
Address	SHDC Environmental Protection

Date Submitted	18-05-26
For/Against	Comments

The Nova acoustics residential noise assessment plan NP-012186 has been considered. this advises that the night time noise levels are exceeded at this location and that non opening windows are advised. as this would risk overheating they advise MVHR system be installed to reduce this.
the findings of this report should be considered for this development