PLATINUM ROOFING SPECIALIST ABOVE THE REST

01778 348830
07930941112

5 Earl Mews
Market Deeping
PE6 8FQ

Date: 24/04/2025

For Attention of: Nat

Job Address: 71 Albion Street, Spalding, PE11 2AU

Payment Terms: 7 days upon receipt of Invoice

Description	Materials	Labour	Cost
Analyse Cement.			
After gaining access to the roof and inspecting the cement to the main ridge line. I can see the mix has either white cement in or lime added to it. My opinion on the sand and cement mix would be that it contains lime as the ridge line has mossed up over time.			
		Total	

Platinum Roofing Specialist

Yours Sincerely,

Mr C Bristowe