Online Comment

Application	H16-0462-24
Location	Castle Sports Complex Albion Street Spalding PE11 2AJ
Proposal	Demolition of existing swimming pool building following the construction of a two storey extension including basement area to existing Castle Sports Complex building to provide new and upgrade indoor leisure and health related facilities including two new swimming pools, plant area and changing rooms. Reconfiguration of existing building to provide new and upgraded sports facilities and physical activity facilities and related supporting services. Provision of a new 3G artificial turf pitch (ATP), an Informal Outdoor Games Area (IOGA), other outdoor play areas, an informal running trail/track, a health and well being garden and an outdoor splash pad relating to the new swimming pool. The provision of supporting infrastructure including additional car parking and landscaped areas.

Name	Diane Gordon
Address	SHDC Environmental Protection
Date Submitted	26-06-24
For/Against	Comments

details regarding noise rating of all swimming pool plant should be submitted prior to commencement to ensure appropriate noise attenuation is put in place.
the noise report of 24.5.24 recommendations regarding the AGP have advised that a number of residential properties are likely to be subjected to levels in excess of 50dB and should therefore be appropriately screened by acoustic fencing to a height of 2m at a B2 or B3 rating.
these measures are to protect the amenity of nearby residents.