

RCD		Page 1
18 Deyley Way Singleton Ashford TN23 5HX	1151-1004 KINGS ROAD SPALDING	
Date MAR 2015 File 1151-1004.mdx	Designed By RAC Checked By	
Micro Drainage	Network W.12.4	

STORM SEWER DESIGN by the Modified Rational Method

Design Criteria for Storm

Pipe Sizes STANDARD Manhole Sizes STANDARD

FSR Rainfall Model - England and Wales

Return Period (years)	2	Add Flow / Climate Change (%)	0
M5-60 (mm)	20.000	Minimum Backdrop Height (m)	0.000
Ratio R	0.350	Maximum Backdrop Height (m)	10.000
Maximum Rainfall (mm/hr)	50	Min Design Depth for Optimisation (m)	1.200
Foul Sewage (l/s/ha)	0.00	Min Vel for Auto Design only (m/s)	1.00
Volumetric Runoff Coeff.	0.750	Min Slope for Optimisation (1:X)	500

Designed with Level Soffits

Time Area Diagram for Storm

Time (mins)	Area (ha)	Time (mins)	Area (ha)
0-4	0.128	4-8	0.033

Total Area Contributing (ha) = 0.161

Total Pipe Volume (m³) = 28.511

Network Design Table for Storm

PN	Length (m)	Fall (m)	Slope (1:X)	Area (ha)	T.E. (mins)	DWF (l/s)	k (mm)	HYD SECT	DIA (mm)
1.000	11.300	0.100	113.0	0.013	5.00	0.0	0.600	o	150
1.001	11.500	0.100	115.0	0.000	0.00	0.0	0.600	o	150
1.002	33.700	0.090	374.4	0.000	0.00	0.0	0.600	o	600
1.003	6.700	0.020	335.0	0.051	0.00	0.0	0.600	o	600
1.004	36.600	0.090	406.7	0.000	0.00	0.0	0.600	o	600
1.005	17.300	0.050	346.0	0.000	0.00	0.0	0.600	o	600

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ Area (ha)	Σ DWF (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
1.000	50.00	5.20	2.700	0.013	0.0	0.0	0.0	0.94	16.7	1.8
1.001	50.00	5.40	2.600	0.013	0.0	0.0	0.0	0.94	16.5	1.8
1.002	50.00	5.85	2.050	0.013	0.0	0.0	0.0	1.25	354.1	1.8
1.003	50.00	5.94	1.960	0.064	0.0	0.0	0.0	1.32	374.6	8.7
1.004	50.00	6.44	1.940	0.064	0.0	0.0	0.0	1.20	339.7	8.7
1.005	50.00	6.67	1.850	0.064	0.0	0.0	0.0	1.30	368.5	8.7

RCD		Page 2																																																																																				
18 Deyley Way Singleton Ashford TN23 5HX	1151-1004 KINGS ROAD SPALDING																																																																																					
Date MAR 2015 File 1151-1004.mdx	Designed By RAC Checked By																																																																																					
Micro Drainage	Network W.12.4																																																																																					
<u>Network Design Table for Storm</u> <table><tr><th>PN</th><th>Length (m)</th><th>Fall (m)</th><th>Slope (1:X)</th><th>Area (ha)</th><th>T.E. (mins)</th><th>DWF (l/s)</th><th>k (mm)</th><th>HYD SECT</th><th>DIA (mm)</th></tr><tr><td>2.000</td><td>13.800</td><td>0.100</td><td>138.0</td><td>0.018</td><td>5.00</td><td>0.0</td><td>0.600</td><td>o</td><td>150</td></tr><tr><td>2.001</td><td>19.600</td><td>0.150</td><td>130.7</td><td>0.079</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>150</td></tr><tr><td>1.006</td><td>12.100</td><td>0.450</td><td>26.9</td><td>0.000</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>300</td></tr></table> <u>Network Results Table</u> <table><tr><th>PN</th><th>Rain (mm/hr)</th><th>T.C. (mins)</th><th>US/IL (m)</th><th>Σ Area (ha)</th><th>Σ DWF (l/s)</th><th>Foul (l/s)</th><th>Add Flow (l/s)</th><th>Vel (m/s)</th><th>Cap (l/s)</th><th>Flow (l/s)</th></tr><tr><td>2.000</td><td>50.00</td><td>5.27</td><td>2.500</td><td>0.018</td><td>0.0</td><td>0.0</td><td>0.0</td><td>0.85</td><td>15.1</td><td>2.4</td></tr><tr><td>2.001</td><td>50.00</td><td>5.64</td><td>2.400</td><td>0.097</td><td>0.0</td><td>0.0</td><td>0.0</td><td>0.88</td><td>15.5</td><td>13.1</td></tr><tr><td>1.006</td><td>50.00</td><td>6.73</td><td>1.800</td><td>0.161</td><td>0.0</td><td>0.0</td><td>0.0</td><td>3.04</td><td>215.2</td><td>21.8</td></tr></table>			PN	Length (m)	Fall (m)	Slope (1:X)	Area (ha)	T.E. (mins)	DWF (l/s)	k (mm)	HYD SECT	DIA (mm)	2.000	13.800	0.100	138.0	0.018	5.00	0.0	0.600	o	150	2.001	19.600	0.150	130.7	0.079	0.00	0.0	0.600	o	150	1.006	12.100	0.450	26.9	0.000	0.00	0.0	0.600	o	300	PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ Area (ha)	Σ DWF (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)	2.000	50.00	5.27	2.500	0.018	0.0	0.0	0.0	0.85	15.1	2.4	2.001	50.00	5.64	2.400	0.097	0.0	0.0	0.0	0.88	15.5	13.1	1.006	50.00	6.73	1.800	0.161	0.0	0.0	0.0	3.04	215.2	21.8
PN	Length (m)	Fall (m)	Slope (1:X)	Area (ha)	T.E. (mins)	DWF (l/s)	k (mm)	HYD SECT	DIA (mm)																																																																													
2.000	13.800	0.100	138.0	0.018	5.00	0.0	0.600	o	150																																																																													
2.001	19.600	0.150	130.7	0.079	0.00	0.0	0.600	o	150																																																																													
1.006	12.100	0.450	26.9	0.000	0.00	0.0	0.600	o	300																																																																													
PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ Area (ha)	Σ DWF (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)																																																																												
2.000	50.00	5.27	2.500	0.018	0.0	0.0	0.0	0.85	15.1	2.4																																																																												
2.001	50.00	5.64	2.400	0.097	0.0	0.0	0.0	0.88	15.5	13.1																																																																												
1.006	50.00	6.73	1.800	0.161	0.0	0.0	0.0	3.04	215.2	21.8																																																																												
©1982-2010 Micro Drainage Ltd																																																																																						

RCD		Page 3						
18 Deyley Way Singleton Ashford TN23 5HX		1151-1004 KINGS ROAD SPALDING						
Date MAR 2015 File 1151-1004.mdx		Designed By RAC Checked By						
Micro Drainage		Network W.12.4						
Manhole Schedules for Storm								
MH Name	MH CL (m)	MH Depth (m)	MH Diam., L*W (mm)	Pipe Out PN Invert Level (m)	Diameter (mm)	Pipes In PN Invert Level (m)	Diameter (mm)	Backdrop (mm)
S1	3.750	1.050	1200	1.000	2.700	150		
S2	3.750	1.150	1200	1.001	2.600	150	1.000	2.600
S3	3.750	1.700	1500	1.002	2.050	600	1.001	2.500
S4	3.500	1.540	1800	1.003	1.960	600	1.002	1.960
S5	3.550	1.610	1500	1.004	1.940	600	1.003	1.940
S6	3.500	1.650	1500	1.005	1.850	600	1.004	1.850
S7	3.300	0.800	1500	2.000	2.500	150		
S8	3.250	0.850	1500	2.001	2.400	150	2.000	2.400
S9	3.400	1.600	1250 x 1250	1.006	1.800	300	1.005	1.800
							2.001	2.250
S13	3.400	2.050	1500		OUTFALL		1.006	1.350
								300
©1982-2010 Micro Drainage Ltd								

RCD		Page 4
18 Deyley Way Singleton Ashford TN23 5HX	1151-1004 KINGS ROAD SPALDING	
Date MAR 2015 File 1151-1004.mdx	Designed By RAC Checked By	
Micro Drainage	Network W.12.4	

PIPELINE SCHEDULES for Storm

Upstream Manhole

PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH DIAM., L*W (mm)
1.000	o	150	S1	3.750	2.700	0.900	1200
1.001	o	150	S2	3.750	2.600	1.000	1200
1.002	o	600	S3	3.750	2.050	1.100	1500
1.003	o	600	S4	3.500	1.960	0.940	1800
1.004	o	600	S5	3.550	1.940	1.010	1500
1.005	o	600	S6	3.500	1.850	1.050	1500
2.000	o	150	S7	3.300	2.500	0.650	1500
2.001	o	150	S8	3.250	2.400	0.700	1500
1.006	o	300	S9	3.400	1.800	1.300	1250 x 1250

Downstream Manhole

PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH DIAM., L*W (mm)
1.000	11.300	113.0	S2	3.750	2.600	1.000	1200
1.001	11.500	115.0	S3	3.750	2.500	1.100	1500
1.002	33.700	374.4	S4	3.500	1.960	0.940	1800
1.003	6.700	335.0	S5	3.550	1.940	1.010	1500
1.004	36.600	406.7	S6	3.500	1.850	1.050	1500
1.005	17.300	346.0	S9	3.400	1.800	1.000	1250 x 1250
2.000	13.800	138.0	S8	3.250	2.400	0.700	1500
2.001	19.600	130.7	S9	3.400	2.250	1.000	1250 x 1250
1.006	12.100	26.9	S13	3.400	1.350	1.750	1500

Free Flowing Outfall Details for Storm

Outfall Pipe Number	Outfall Name	C. Level (m)	I. Level (m)	Min I. Level (m)	D,L (mm)	W (mm)
1.006	S13	3.400	1.350	1.350	1500	0

RCD		Page 5																																																								
18 Deyley Way Singleton Ashford TN23 5HX	1151-1004 KINGS ROAD SPALDING																																																									
Date MAR 2015 File 1151-1004.mdx	Designed By RAC Checked By																																																									
Micro Drainage		Network W.12.4																																																								
<u>Simulation Criteria for Storm</u> <table> <tr> <td>Volumetric Runoff Coeff</td> <td>0.840</td> <td>Foul Sewage per hectare (l/s)</td> <td>0.000</td> </tr> <tr> <td>PIMP (% impervious)</td> <td>100</td> <td>Additional Flow - % of Total Flow</td> <td>30.000</td> </tr> <tr> <td>Areal Reduction Factor</td> <td>1.000</td> <td>MADD Factor * 10m³/ha Storage</td> <td>2.000</td> </tr> <tr> <td>Hot Start (mins)</td> <td>0</td> <td>Run Time (mins)</td> <td>240</td> </tr> <tr> <td>Hot Start Level (mm)</td> <td>0</td> <td>Output Interval (mins)</td> <td>4</td> </tr> <tr> <td>Manhole Headloss Coeff (Global)</td> <td>0.500</td> <td></td> <td></td> </tr> </table> <table> <tr> <td>Number of Input Hydrographs</td> <td>0</td> <td>Number of Storage Structures</td> <td>1</td> </tr> <tr> <td>Number of Online Controls</td> <td>1</td> <td>Number of Time/Area Diagrams</td> <td>0</td> </tr> <tr> <td>Number of Offline Controls</td> <td>0</td> <td></td> <td></td> </tr> </table> <u>Synthetic Rainfall Details</u> <table> <tr> <td>Rainfall Model</td> <td>FSR</td> <td>Profile Type</td> <td>Winter</td> </tr> <tr> <td>Return Period (years)</td> <td>30</td> <td>Cv (Summer)</td> <td>0.750</td> </tr> <tr> <td>Region</td> <td>England and Wales</td> <td>Cv (Winter)</td> <td>0.840</td> </tr> <tr> <td>M5-60 (mm)</td> <td>20.000</td> <td>Storm Duration (mins)</td> <td>120</td> </tr> <tr> <td>Ratio R</td> <td>0.350</td> <td></td> <td></td> </tr> </table>			Volumetric Runoff Coeff	0.840	Foul Sewage per hectare (l/s)	0.000	PIMP (% impervious)	100	Additional Flow - % of Total Flow	30.000	Areal Reduction Factor	1.000	MADD Factor * 10m³/ha Storage	2.000	Hot Start (mins)	0	Run Time (mins)	240	Hot Start Level (mm)	0	Output Interval (mins)	4	Manhole Headloss Coeff (Global)	0.500			Number of Input Hydrographs	0	Number of Storage Structures	1	Number of Online Controls	1	Number of Time/Area Diagrams	0	Number of Offline Controls	0			Rainfall Model	FSR	Profile Type	Winter	Return Period (years)	30	Cv (Summer)	0.750	Region	England and Wales	Cv (Winter)	0.840	M5-60 (mm)	20.000	Storm Duration (mins)	120	Ratio R	0.350		
Volumetric Runoff Coeff	0.840	Foul Sewage per hectare (l/s)	0.000																																																							
PIMP (% impervious)	100	Additional Flow - % of Total Flow	30.000																																																							
Areal Reduction Factor	1.000	MADD Factor * 10m³/ha Storage	2.000																																																							
Hot Start (mins)	0	Run Time (mins)	240																																																							
Hot Start Level (mm)	0	Output Interval (mins)	4																																																							
Manhole Headloss Coeff (Global)	0.500																																																									
Number of Input Hydrographs	0	Number of Storage Structures	1																																																							
Number of Online Controls	1	Number of Time/Area Diagrams	0																																																							
Number of Offline Controls	0																																																									
Rainfall Model	FSR	Profile Type	Winter																																																							
Return Period (years)	30	Cv (Summer)	0.750																																																							
Region	England and Wales	Cv (Winter)	0.840																																																							
M5-60 (mm)	20.000	Storm Duration (mins)	120																																																							
Ratio R	0.350																																																									
©1982-2010 Micro Drainage Ltd																																																										

RCD		Page 6																																																																								
18 Deyley Way Singleton Ashford TN23 5HX	1151-1004 KINGS ROAD SPALDING																																																																									
Date MAR 2015 File 1151-1004.mdx	Designed By RAC Checked By																																																																									
Micro Drainage	Network W.12.4																																																																									
<u>Online Controls for Storm</u> <u>Hydro-Brake® Manhole: S9, DS/PN: 1.006, Volume (m³): 7.3</u> Design Head (m) 1.000 Diameter (mm) 94 Design Flow (l/s) 5.0 Invert Level (m) 1.800 Hydro-Brake® Type Md6 SW Only <table border="1"> <thead> <tr> <th>Depth (m)</th> <th>Flow (l/s)</th> <th>Depth (m)</th> <th>Flow (l/s)</th> <th>Depth (m)</th> <th>Flow (l/s)</th> <th>Depth (m)</th> <th>Flow (l/s)</th> </tr> </thead> <tbody> <tr> <td>0.100</td> <td>2.8</td> <td>1.200</td> <td>5.5</td> <td>3.000</td> <td>8.8</td> <td>7.000</td> <td>13.4</td> </tr> <tr> <td>0.200</td> <td>4.1</td> <td>1.400</td> <td>6.0</td> <td>3.500</td> <td>9.5</td> <td>7.500</td> <td>13.8</td> </tr> <tr> <td>0.300</td> <td>3.9</td> <td>1.600</td> <td>6.4</td> <td>4.000</td> <td>10.1</td> <td>8.000</td> <td>14.3</td> </tr> <tr> <td>0.400</td> <td>3.8</td> <td>1.800</td> <td>6.8</td> <td>4.500</td> <td>10.7</td> <td>8.500</td> <td>14.7</td> </tr> <tr> <td>0.500</td> <td>3.8</td> <td>2.000</td> <td>7.1</td> <td>5.000</td> <td>11.3</td> <td>9.000</td> <td>15.2</td> </tr> <tr> <td>0.600</td> <td>4.0</td> <td>2.200</td> <td>7.5</td> <td>5.500</td> <td>11.9</td> <td>9.500</td> <td>15.6</td> </tr> <tr> <td>0.800</td> <td>4.5</td> <td>2.400</td> <td>7.8</td> <td>6.000</td> <td>12.4</td> <td></td> <td></td> </tr> <tr> <td>1.000</td> <td>5.1</td> <td>2.600</td> <td>8.1</td> <td>6.500</td> <td>12.9</td> <td></td> <td></td> </tr> </tbody> </table>			Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	0.100	2.8	1.200	5.5	3.000	8.8	7.000	13.4	0.200	4.1	1.400	6.0	3.500	9.5	7.500	13.8	0.300	3.9	1.600	6.4	4.000	10.1	8.000	14.3	0.400	3.8	1.800	6.8	4.500	10.7	8.500	14.7	0.500	3.8	2.000	7.1	5.000	11.3	9.000	15.2	0.600	4.0	2.200	7.5	5.500	11.9	9.500	15.6	0.800	4.5	2.400	7.8	6.000	12.4			1.000	5.1	2.600	8.1	6.500	12.9		
Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)																																																																			
0.100	2.8	1.200	5.5	3.000	8.8	7.000	13.4																																																																			
0.200	4.1	1.400	6.0	3.500	9.5	7.500	13.8																																																																			
0.300	3.9	1.600	6.4	4.000	10.1	8.000	14.3																																																																			
0.400	3.8	1.800	6.8	4.500	10.7	8.500	14.7																																																																			
0.500	3.8	2.000	7.1	5.000	11.3	9.000	15.2																																																																			
0.600	4.0	2.200	7.5	5.500	11.9	9.500	15.6																																																																			
0.800	4.5	2.400	7.8	6.000	12.4																																																																					
1.000	5.1	2.600	8.1	6.500	12.9																																																																					
©1982-2010 Micro Drainage Ltd																																																																										

RCD		Page 7																		
18 Deyley Way Singleton Ashford TN23 5HX	1151-1004 KINGS ROAD SPALDING																			
Date MAR 2015 File 1151-1004.mdx	Designed By RAC Checked By																			
Micro Drainage		Network W.12.4																		
<u>Storage Structures for Storm</u> <u>Cellular Storage Manhole: S6, DS/PN: 1.005</u> Invert Level (m) 1.900 Safety Factor 2.0 Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95 Infiltration Coefficient Side (m/hr) 0.00000 <table border="1"> <thead> <tr> <th>Depth (m)</th> <th>Area (m²)</th> <th>Inf. Area (m²)</th> <th>Depth (m)</th> <th>Area (m²)</th> <th>Inf. Area (m²)</th> </tr> </thead> <tbody> <tr> <td>0.000</td> <td>24.0</td> <td>24.0</td> <td>1.001</td> <td>0.0</td> <td>43.6</td> </tr> <tr> <td>1.000</td> <td>24.0</td> <td>43.6</td> <td></td> <td></td> <td></td> </tr> </tbody> </table>			Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)	0.000	24.0	24.0	1.001	0.0	43.6	1.000	24.0	43.6			
Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)															
0.000	24.0	24.0	1.001	0.0	43.6															
1.000	24.0	43.6																		
©1982-2010 Micro Drainage Ltd																				

RCD		Page 8						
18 Deyley Way Singleton Ashford TN23 5HX	1151-1004 KINGS ROAD SPALDING							
Date MAR 2015 File 1151-1004.mdx	Designed By RAC Checked By							
Micro Drainage	Network W.12.4							
<u>Summary of Results for 120 minute 30 year Winter (Storm)</u>								
Margin for Flood Risk Warning (mm)		450.0						
Analysis Timestep 2.5 Second Increment (Extended)								
DTS Status		ON						
DVD Status		ON						
Inertia Status		OFF						
	Water	Surcharged	Flooded			Pipe		
	US/MH	Level	Depth	Volume	Flow /	Overflow	Flow	
PN	Name	(m)	(m)	(m³)	Cap.	(l/s)	(l/s)	Status
1.000	S1	2.735	-0.115	0.000	0.12	0.0	1.9	OK
1.001	S2	2.635	-0.115	0.000	0.12	0.0	1.9	OK
1.002	S3	2.478	-0.172	0.000	0.00	0.0	1.4	OK
1.003	S4	2.478	-0.082	0.000	0.03	0.0	4.9	OK
1.004	S5	2.477	-0.063	0.000	0.02	0.0	4.4	OK
1.005	S6	2.477	0.027	0.000	0.01	0.0	3.7	SURCHARGED
2.000	S7	2.545	-0.105	0.000	0.19	0.0	2.6	OK
2.001	S8	2.516	-0.034	0.000	0.95	0.0	13.9	OK
1.006	S9	2.477	0.377	0.000	0.03	0.0	4.2	SURCHARGED
©1982-2010 Micro Drainage Ltd								