



Planning Application – Anglian Water Response

If you would like to discuss any of the points in this document please contact us on 03450263912 or email planningliaison@anglianwater.co.uk.

AW Site Reference:	226127/1/0228375
Local Planning Authority:	South Holland District
Site:	Land at Horseshoe Road Spalding PE11 3JB
Proposal:	Residential development of 76 dwellings and associated infrastructure
Planning application:	H16-0515-25

Prepared by: Pre-Development Team

Date: 23 June 2025

ASSETS

Section 1 - Assets Affected

There are assets owned by Anglian Water or those subject to an adoption agreement within or close to the development boundary that may affect the layout of the site. Anglian Water would ask that the following text be included within your Notice should permission be granted. Anglian Water has assets close to or crossing this site or there are assets subject to an adoption agreement. Therefore the site layout should take this into account and accommodate those assets within either prospectively adoptable highways or public open space. If this is not practicable then the sewers will need to be diverted at the developers cost under Section 185 of the Water Industry Act 1991. or, in the case of apparatus under an adoption agreement, liaise with the owners of the apparatus. It should be noted that the diversion works should normally be completed before development can commence.

WASTEWATER SERVICES

Section 2 - Wastewater Treatment - Condition

This site is within the catchment of Spalding Water Recycling Centre (WRC), which currently can accommodate the additional flows generated by the proposed development. Spalding WRC is included within our Business Plan as a named growth scheme with investment delivery planned between 2025-2030. To ensure there is no pollution or deterioration in the receiving watercourse due to the development foul flows we recommend a planning condition is applied if permission is granted.

Condition: Prior to occupation written confirmation from Anglian Water must be submitted confirming there is sufficient headroom at the water recycling centre to accommodate the foul flows from the development site. This condition shall cease to have effect if the development is first occupied after April 2030.

Reason: To protect water quality, prevent pollution and secure sustainable development having regard to paragraphs 7/8 and 187 of the National Planning Policy Framework

Section 3 - Used Water Network

This response has been based on the following submitted documents: Flood Risk Assessment ECL1393/Seagate Homes December 2024 -Final report and Drainage strategy 12887 - WMS - ZZ - XX - D - C - 39201 - S8 - P6 The sewerage system at present has available capacity for these flows. If the developer wishes to connect to our sewerage network they should serve notice under Section 106 of the Water Industry Act 1991. We will then advise them of the most suitable point of connection.

1. INFORMATIVE - Notification of intention to connect to the public sewer under S106 of the Water Industry Act Approval and consent will be required by Anglian Water, under the Water Industry Act 1991. Contact Development Services Team 0345 606 6087 Option 2. 2. INFORMATIVE - Protection of existing assets - If a public sewer is shown on record plans within the land identified for the proposed development. It appears that development proposals will affect existing public sewers. It is recommended that the applicant contacts Anglian Water Development Services Team for further advice on this matter. Building over existing public sewers will not be permitted (without agreement) from Anglian Water. 3. INFORMATIVE - Building near to a public sewer - No building will be permitted within the statutory easement width of 3 metres from the pipeline without agreement from Anglian Water. Please contact Development Services Team on 0345 606 6087 Option 2. 4. INFORMATIVE: The developer should note that the site drainage details submitted have not been approved for the purposes of adoption. If the developer wishes to have the sewers included in a sewer adoption agreement with Anglian Water (under Sections 104 of the Water Industry Act 1991), they should contact our Development Services Team on 0345 606 6087 Option 2 at the earliest opportunity. Sewers intended for adoption should be designed and constructed in accordance with Sewers for Adoption guide for developers, as supplemented by Anglian Water's requirements.

Section 4 - Surface Water Disposal

The applicant has indicated on their application form that their method of surface water drainage is via SuDS with an outfall into an existing watercourse. If the developer wishes Anglian Water to be the adopting body for all or part of the proposed SuDS scheme the Design and Construction Guidance must be followed. We would recommend the applicant contact us at the earliest opportunity to discuss their SuDS design via a Pre-Design Strategic Assessment (PDSA). The Lead Local Flood Authority (LLFA) are a statutory consultee for all major development and should be consulted as early as possible to ensure the proposed drainage system meets with minimum operational standards and is beneficial for all concerned organisations and individuals. We promote the use of SuDS as a sustainable and natural way of controlling surface water run-off. We please find below our SuDS website link for further information. <https://www.anglianwater.co.uk/developers/drainage-services/sustainable-drainage-systems/>

Anglian Water's Environmental Incentive Scheme (EIS)

Anglian Water's Environmental Incentive Scheme (EIS) has been developed in accordance with the Environmental Incentive Common Framework (EICF), which was released by Ofwat in December 2024. For this charging year, 2025-26, and in accordance with Ofwat guidance, only household properties will be eligible for our EIS. We will continue to reassess this for future charging years. There are then two types of Environmental Incentive in our EIS. The first is our Water Environmental Incentive and the second is our Sewerage Environmental Incentive.

Environmental Incentives	Charge Per Property
Water Environmental Incentive	-500
Sewerage Environmental Incentive (50% of Sewerage Infra)	-202
Environmental Incentive Component Charge Water	100
Environmental Incentive Component Charge Sewerage	0
Additional Water EIS Audit (per premises)	84

Our EIS will be available between 1st April 2025 and 31st March 2030 and during this period, we reserve the right to make any amendments to the EIS as we may see fit, including amendments to the value of both Environmental Incentives and the Component Charges. The EIS may close on 31st March 2030, therefore to qualify for the Environmental Incentives, your plot must be connected to our network, and validated by us. Please refer to our Developer Charging Arrangements for full details. To learn more or apply for our environmental incentive scheme please visit our website: [Water Environmental Incentive Scheme](#)