



Town and Country Planning Act 1990

Planning Permission

Reference: H16/0541/96

Received: 07-JUN-96 Type: FULL

Name: Fowler Welch Ltd
Holly Lodge
West Marsh Road
Spalding
Lincs

Agent: Fowler Welch Ltd
Holly Lodge
West Marsh Road
Spalding
Lincs

Description: Proposed plant room

Location : West Marsh Road Spalding
Lincs

South Holland District Council hereby give notice that PERMISSION HAS BEEN GRANTED for the development in accordance with the application and plans submitted, subject to any condition(s) set out below:

- 1 The development must be begun not later than the expiration of five years beginning with the date of this permission.

Reason: As required by Section 91 of the Town and Country Planning Act 1990.

- 2 Noise from static plant and machinery shall not exceed a level equivalent to 35 LAeq 15 minutes when measured at a height of 2 metres and at a distance of 3.5 metres from any residential facade.

Reason: To safeguard the amenities of dwellings.

Director of Housing and Planning Services
31-JUL-96 H16/0541/96

This decision refers only to that required for the purposes of the Town and Country Planning Act and not for Building Regulations or any other legislation. See enclosed notes relating to rights of appeal.

NB: Termination Date

Town and Country Planning Act etc

DRAFT PERMISSION

Reference: H16/0541/96

Received: 07-JUN-96 Type: FULL

Name: Fowler Welch Ltd
Holly Lodge
West Marsh Road
Spalding
Lincs

Agent: Fowler Welch Ltd
Holly Lodge
West Marsh Road
Spalding
Lincs

Description: Proposed plant room

Location : West Marsh Road Spalding
Lincs

South Holland District Council hereby give notice
that permission has been granted (or equiv)
on the following condition(s):

- 1 The development must be begun not later than the expiration of five years beginning with the date of this permission.

Reason: As required by Section 91 of the Town and Country Planning Act 1990.

- ^{and}
2 Noise from static plant machinery shall not exceed a level equivalent to 35 LAeq 15 minutes when measured at a height of 2 metres and at a distance of 3.5 metres from any residential facade.

Reason: To safeguard the amenities of dwellings.

30-JUL-96

Checked ... ~~22.30/7~~ ..

30/7

Authorised to issue (inc Delegation) ... ~~22.30/7~~ ..