

Online Comment

Application H16-0552-26
Location Land off Shakespeare Way Holland Park Spalding PE11 1GU
Proposal Erection of a 3-storey care home development with associated car parking, amenity space and ancillary structures

Name Oliver Abrams
Address SHDC Environmental Protection Officer

Date Submitted 17-07-26
For/Against Comments

I have reviewed Dice Environmental, Phase 1 and 2 Ground Investigation Report for Holland Park, Spalding, Lincolnshire, PE11 1GU, Project Reference: 102378, Document Reference: HOL-DEL-XX-XX-RP-GE-0001, Dated: 12/05/2026. I am in agreement with this report that no remediation in regards to land contamination is required and therefore recommend that this condition is discharged.

However In the event that contamination is found at any time when carrying out the approved development that was not previously identified it must be reported immediately to the Local Planning Authority (LPA). An investigation and risk assessment must be undertaken in accordance with details to be agreed with the LPA. Where remediation is necessary, a remediation scheme must be submitted to and approved in writing by the LPA. Following completion of measures identified in the approved remediation scheme a verification report shall be submitted to and approved by the LPA.

No deviation shall be made from this scheme without the express written agreement of the LPA. If during redevelopment contamination not previously considered is identified, then the LPA shall be notified immediately and no further work shall be carried out until a method statement detailing a scheme for dealing with the suspected contamination has been submitted to and agreed in writing by the LPA.

Reason: To assess whether the site is polluted and to address any pollution to ensure a satisfactory development. This issue is integral to the development and therefore full details need to be finalised prior to the commencement of works.