# Online Comment

| | |
|---|---|
| **Application** | H16-0565-17 |
| **Location** | Co-op Supermarket 1 Clover Way Spalding PE11 3GD |
| **Proposal** | Replacement plant installation |

---

| | |
|---|---|
| **Name** | Steve Branson |
| **Address** | Environmental Health Technician Safety and Environment |

| | |
|---|---|
| **Date Submitted** | 18-07-17 |
| **For/Against** | Comments |

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5 dB(A) when measured as a 15 minute L(A)eq at any residential boundary.