

Online Comment

Application	H16-0566-18
Location	TANGLEWOOD CEDAR FALLS CARE HOME LITTLE LONDON SPALDING PE11 2UA
Proposal	Building to house a biomass boiler system and pellet storage area, to provide up to 220kW energy to the Care Home (retrospective)

Name	Steve Branson
Address	SHDC Priory Road

Date Submitted	21-06-18
For/Against	Comments

No objection but would request the following condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.