




Key:	
	Existing Combined Sewer - AWA
	Proposed Combined Manhole - Adoptable
	Proposed Combined Sewer - Adoptable
	Proposed Foul Sewer - Adoptable
	Proposed Foul Manhole - Adoptable
	Proposed Foul Lateral Drain
	Proposed Foul Inspection Chamber
	Proposed Foul Drain - Private
	Proposed Foul Inspection Chamber - Private
	Proposed Surface Water Drain - Private
	Proposed Surface Water Inspection Chamber - Private
	Proposed Surface Water Drain Rodding Eye
	Proposed Surface Water Sewer - Adoptable
	Proposed Surface Water Manhole - Adoptable
	Proposed Highway Drain
	Proposed Highway Drain Manhole
	Proposed Highway Gully
	Proposed Sookaway Crates
	Existing Site Level
	Proposed Site Level
	Proposed High Point
	Proposed Low Point

Attenuation Volume @ 2.900 Water Level:	
• 300# Storage Pipe = 2.08m ³	
• 375# Storage Pipe = 2.77m ³	
• 4 No. Manholes = 1.29m ³	
Total = 6.14m ³	

Rev	Date	Remarks
B	25.01.16	Drawing Updated In Accordance With LCC & Anglian Water Comments.
A	08.01.16	Proposed Street Lighting Added.
Status		
FOR INFORMATION		
Project		
Proposed Residential Development Off Green Lane, Spalding, Lincs.		
For D&R Property Services Ltd.		
Title		
Proposed Drainage Layout		
Date		
Nov. '15	Scale	1:200 @A1
Drawn	MP	Checked SRC
Design	SRC	File Name 14015-21
DRG No. 14015/21		Rev B