Online Comment

Application	H16-0580-17
Location	2 ST JOHNS ROAD SPALDING PE11 1JB
Proposal	Details submitted relating to Conditions 3, 4, 6, 7, 8, 9, 10, 13, 14, 15, 16, 17 and 19 of H16-1083-16

Name	J Reith
Address	Environmental Health Technician Safety and Environment

Date Submitted	13-07-17
For/Against	Comments

The Combined Phase I and Phase II Ground Investigation by Mewies Engineering Consultants Limited dated November 2016 recommends that further testing is carried out on site post demolition and therefore the condition cannot be discharged at this stage. Once the further testing has been carried out the applicant should submit a remediation method statement prior to the construction of the development.
The report also recommends an asbestos survey prior to demolition.
I would also like further information, if possible, on the nature of the five storage tanks detailed on the 1968 map and if/when they were decommissioned.