Online Comment

Application	H16-0580-17
Location	2 ST JOHNS ROAD SPALDING PE11 1JB
Proposal	Details submitted relating to Conditions 3, 4, 6, 7, 8, 9, 10, 13, 14, 15, 16, 17 and 19 of H16-1083-16

Name	J Reith
Address	Environmental Health Technician Safety and Environment
Date Submitted	20-10-17
For/Against	Comments

I have considered the extra information provided with Amendment 4 and can confirm that I now have the information relating to the extra gas monitoring on site. This completes parts i and ii of the condition for contamination.
However I have not received a separate remediation method statement to summarise the remediation requirements for the site and the mitigation needed in the properties. This is necessary to fulfil part iii of the condition.
I also had a query about whether there were underground fuel tanks on the site and this hasn't been answered.
I have had a notification this week from the Contracts Manager at GEDA that they have discovered that what they thought was a hydrocarbon 'hotspot' is more expansive. I have a meeting on Thursday 26 October to discuss how this will be dealt with.
Due to the above the full condition cannot be discharged at this time.