



GROUND FLOOR

1ST. FLOOR


2ND. FLOOR
(not used)




SECTION B-B

PLANS AS EXISTING


SCALE 1:100



GROUND FLOOR PLAN



1ST. FLOOR PLAN



SECTION A-A

Headroom to stair

Gnd Floor to Floor	3070		
1st Floor to newel	1420		
	4490		
tread 12 height	2166	=	2324
tread 13 "	2347	=	2143
tread 14 "	2528	=	1962

min headroom allowed by BS 5395 pt 2 is 1.90m ∴ OK

SHDC
Planning & Development
22 AUG 2011
Ref. 0587-11

NEW STAIRCASE AT SHOOTERS BAR SPALDING

8215/G/3. SCALE 1:50

MOLSOM & PARTNERS
SURVEYORS
13. MAIN RIDGE. BOSTON. LINCS.