Online Comment

Application	H16-0684-19
Location	Land to the North of Witham Road Wygate Park Spalding PE11 3QE
Proposal	Details of scheme to prevent ingress of hazardous ground gases to buildings, site and floor levels, details of levelling of open space, additional safety measures around swale, design and position of external boxes etc (Conditions 3, 8, 9, 10, 12 and 21 of H16-1117-18)

Name	Sue Armour
Address	Environmental Protection Officer SHDC, Priory Road Spalding PE11 2XE
Date Submitted	06-08-19
For/Against	Comments

I have reviewed the document 'Installation / system components' and drawings 'STD-SUB-001opt1' & 'STD-SUB-001opt1' and they meet the requirements for NHBC Amber 1 level groudn gas protection measures, however I was expecting further ground gas motioning data and a proposal for validation to accompany these details. Please re-consult me when they are received.