_planningadvice

From: Polly Harris-Gorf
Sent: 20 November 2019 08:16
To: _planningadvice
Subject: FW: Online web comments received for application: H16-0686-19

6SUP(Additional information)

From: Luke Boekestyn <luke.boekestyn@burmor.co.uk>
Sent: 19 November 2019 13:43
To: Polly Harris-Gorf <pharris-gorf@sholland.gov.uk>
Cc: Armour, Susan (SHBK) <Susan.Armour@Breckland-Sholland.gov.uk>
Subject: RE: Online web comments received for application: H16-0686-19

This message originated from outside your organization

Afternoon Polly and Sue,

150mm topsoil capping is to be as per the below specification:

The YALPAG (Local Authority Group) guidance on local capping requirements, including selection, importation, testing and placement of capping layers.

British Standard
Imported topsoils should be as specified in BS 3882:2007 as 'suitable for their intended purpose'. BS3882:2007 relates to nutrient content of topsoil and phytotoxic contamination and does not consider contaminants that pose a risk specifically to human health. Soils should be tested for contaminants that are considered to pose a risk to human health in addition to BS3882:2007 to ensure that they are suitable for their intended use.

Any material beneath this as approved fill will chemical tested by WAC analysis as inert sub-soil, not site won, but imported.

Thanks,

Luke Boekestyn BSc (Hons)
Managing Director

burmor projects

burmor house, sunderland road,
northfields industrial estate,
market deeping, peterborough.
pe6 8fd