Online Comment

Application	H16-0686-19
Location	Land off Willow Walk Spalding
Proposal	Details of landscaping (Condition 6 of H16-0283-17) - Residential development of 20 dwellings

---

Name	Sue Armour
Address	Environmental Protection Officer SHDC, Priory Road Spalding PE11 2XE
Date Submitted	11-11-19
For/Against	Comments

The landscaping plan now details the material to be imported. Therefore I have no further comments at this time.

Regarding the remediation, I have reviewed the two Geomatters letter reports (dated 10/9/2019 & 07/10/2019 and spoken to Alex Thornber today. Alex confirmed that all of the made ground has been removed from site by the contractor, not just in the areas immediately surrounding the boreholes. The area around
WS06 has been dealt with adequately as well. Once validation of the capping layer is received I will be in a position to recommend discharge of condition 3 of H16-0283-17 in full.