

Online Comment

Application H16-0754-17
Location Spalding Energy Expansion Limited West Marsh Road Spalding PE11 2BB
Proposal Details of contaminated waste (Conditions 33 and 34 of H16-0605-17)

Name J Reith
Address Environmental Health Technician Safety and Environment

Date Submitted 06-10-17
For/Against Comments

I have considered the Ground Condition Report by Environ and the other historical site investigation reports which were provided to me separately.
The information provided is satisfactory to discharge conditions 33 and 34, except on page 11 of the Environ Ground Condition report it says 'following completion of the site preparation works, a further gas monitoring exercise will be carried out to inform a detailed gas risk assessment and facilitate the design of gas mitigation measures'. I therefore require this additional gas monitoring information before the conditions can be discharged.