Online Comment

Application	H16-0867-17
Location	Former Welland Hospital Site/Former Garage Holbeach Road Spalding PE11 2HY
Proposal	Erection of a class A1 food store, new access, service yard, car parking, landscaping and associated works

---

Name	Noise and Contaminated Land
Address	Environmental Health Technician Safety and Environment
Date Submitted	26-10-17
For/Against	Comments

The Phase 1 & 2 Investigation Report by CSG (Ref 696-R-01B Dated July 17) meets parts 1 and 2 of the contaminated land condition. The investigation has concluded that remediation is required around the former fuel filling station area. Therefore I request parts 3 and 4 of the contaminated land condition (remediation and validation) for this application.