

Online Comment

Application	H16-0903-22
Location	Opperman Plants Ltd 9-15 Mallard Road Low Fulney PE12 6ND
Proposal	Proposed Glasshouse Development

Name	Steve Branson
Address	SHDC Priory Road

Date Submitted	19-10-22
For/Against	Comments

No objection but request the following condition:
Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.