Online Comment

Application	H16-0918-21
Location	Lincs Gateway Phase 2 Land North of Barrier Bank Spalding PE12 6FY
Proposal	Phase 2 of the Lincs Gateway development, to include 4 office buildings and 24 small industrial units

---

Name	Steve Branson
Address	SHDC Priory Road
Date Submitted	10-11-21
For/Against	Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.