Our Ref: H16/1399/01
GS/MJT
Your Ref: AF2438/2/RJA/L1

Contact: Gordon Smith

W S Atkins Planning Consultants
Wellbrook Court
Girton Road
Cambridge
CB3 0NA

20 December 2001

Dear Mr Atkinson

Spalding Power Station – Condition 20 of Section 36 Content

I refer to your letter dated 12 December 2001.

Matters in that letter relating to amendments to design (as it concerns the sub-station only) have been approved (copy attached).

The purpose of this letter is to confirm that the details of proposed ground preparation methods are satisfactory. We have, however, already approved broader principles of pile driving (Condition 20), and I enclose our decision notice. I am thereby treating your submission as further details of the same, and I confirm their acceptability.

Yours sincerely

Gordon Smith
Development Control Manager

Enclosure

Copy to: Nick Fennel
Dalton Warner Davies
21 Garlick Hill
London
EC4V 2AU

FILE COPY

SOUTH HOLLAND DISTRICT COUNCIL

Chris Simpkins
Chief Executive
Terry Huggins
Director of Customer Services
Bob Atkins
Director of Corporate Services

Application no: H16/0941/01

Original Applicant:
Spalding Energy Company Ltd
81 George Street
Edinburgh
Scotland

Original Agent:
Dalton Warner Davis
21 Garlick Hill
London
EC4V 2AU

Description: Details of siting,design, appearance,colour of materials & surface finishes (Conditions 13 (i) & (ii) of H16/0788/96)

Location: Site for Spalding Power Station (Former British Sugar Factory) West Marsh Road Spalding

Amendment: Sub-Station layout (dwg nos. 90364/816.01/001, /003, /004, /005, /006, /007, /008, PJ2292/1000, /1001 & E/0247-BS A)

18-DEC-01

Dear Sir/Madam

TOWN AND COUNTRY PLANNING ACT 1990

NOTICE OF ACCEPTANCE OF AMENDMENT

The amended details submitted in respect of the above proposal have now been considered and there are no objections to the amendment being implemented to the extent described above.

Note: This Notice does not convey any approval under the Building Regulations and you may need to make a new submission.

Yours faithfully

Director of Customer Services

WS Atkins Planning Consultants
Wellbrook Court
Girton Road
Cambridge
CB3 0NA

Council Offices
Priory Road
Spalding
Lincolnshire
PE11 2XE
Telephone: (01775) 761161
Fax: (01775) 711253
Email: Info@sholland.gov.uk

Steve.

Please book in, and issue approval DN

Drawing Nos are as in their covering letter.

For the record, the scheme represents minor and inconsequential alterations to the approved scheme.
The additional drawings present further information about the scheme already approved, and are acceptable.

Gordon Smith 18/12/01

PLANNING AMENDMENT

For office use only

Application No. H16/0941/01/41

Date Registered 13 DEC 01

Case Officer Gordon SMITH

1. Please complete in block letters

NAME AND ADDRESS OF APPLICANT

Spalding Energy Company
61 George Street
Edinburgh, Scotland

Tel. No.

NAME AND ADDRESS OF AGENT
(if form completed by agent)

W S Atkins Planning Consultants
Woodcote Court, Cotton Road
Cambridge CB1 0NA

Tel. No. (Contact) R.J. Atkinson

Please complete in block letters

FULL POSTAL ADDRESS OF THE APPLICATION SITE

Spalding Power Station, West Marsh Road

Please complete

APPLICATION No. H16/0941/01

This amendment **cannot be considered** unless the relevant reference is stated

Building Regulation reference relating to same development (if any)

2. Please tick **one** box only

A — Amendment is proposed where permission already granted [✓]
If yes, submit two forms and two plans.

or

B — Amendment is to a proposal currently being considered [ ]
If yes, submit four forms and four plans.

Please complete

I attach the necessary plans and request that the changes described below be accepted as an amendment. I understand that the Council may require a fresh application, together with fee if appropriate. If the amendment relates to a current application, I agree to an extension of the terminal date.

Signed (on behalf of applicant) Date 17.12.01

3. Please complete in block letters

FULL DESCRIPTION OF DEVELOPMENT IN ORIGINAL APPLICATION

State details of amendments proposed

(Give a full detailed list of the changes, and also mark these clearly on the accompanying plans. Only the changes listed here will be considered.)

Layout of sub-station

(see letter)

State drawing no's of the current submission

Has this amendment been requested by the Council? (If so, state Officer dealing with the application)

YES / NO

Describe any part of the original development which is excluded by virtue of the amendment, and state any alteration to plot numbers

Has a similar amendment been submitted under Building Regulations? Yes / No

AMENDMENT RECORD SHEET - POST DECISION

Admin

Validation:

Inadequate/Inappropriate ☐

Clarification/Details required:

Appears valid ☑ 17/12/01

Registered .....

DC Procedural Assessment

Is the information given correct? (Yes)/No (If No, state above what details are needed)

Is it an amendment in principle? Immaterial/Needs new app

Confirmed: 17/12/01

Give a revised description if the details accepted are different to the submission:


Acceptance issued: ✓ 18/12

a division of WS Atkins Planning and Management Consultants Limited

Wellbrook Court
Girton Road
Cambridge CB3 0NA England


Tel: +44 (0)1223 276002
Fax: +44 (0)1223 277529
Web: www.wsatkins.com

Your Ref H16/0940/01
Our Ref AF2438/2/RJA/RJA/L1



Date 12 December 2001

South Holland District Council
Housing and Planning Services Department
Priory Road
Spalding
PE11 2XE



For the attention of Gordon Smith

Dear Mr Smith

Spalding Energy Project
National Grid Substation

You have previously received detailed drawings for the National Grid Substation in satisfaction of condition 13 on the section 36 approval. As I previously indicated would be the case, further design development has been taking place and I now enclose two copies of revised drawings showing the substation layout and the different elements of plant and buildings within it. These indicate only minor changes, as set out in the following schedule, which I trust will be acceptable to you.

The perimeter fencing details shown on drawings 34/2855 and 34/2856, previously supplied, remain unchanged.

I also attach details of the proposed ground preparation method in satisfaction of condition 20. *

Please do not hesitate to contact me should you require further information or further copies of any drawings.

Yours faithfully
for and on behalf of
WS Atkins Planning Consultants

* See file H16/399/01

RJ Atkinson
Principal Planner

Original drawing	Subject	Revised drawing	Changes
Revised drawings			
PDH100129N03	Substation layout	90364/816.01/001	Electrical equipment layout and access arrangements essentially the same. 3m wide internal access road provided through the centre of the site to improve maintenance access. Positions of auxiliary building and standby generator handed. Garage for elevated platform added adjacent to generator.
PDH100129N04	Sections through compound	90364/816.01/003 to 008 Rev 0	Minor changes to electrical equipment – unlikely to be discernible to lay person.
NGDWGNO	Auxiliary building elevations	PJ2292/1000	Drawing number change only.
New drawings			
	Mobile elevated working platform garage elevations	PJ2292/001 Rev A	Note materials to match auxiliary building.
	Standby generator plan/elevations	E/0247-BS Rev A	
	Rectangular envirotank with integral cabinet	unnumbered	
	%m relay room plan and section	unnumbered	