Online Comment

Application	H16-0959-21
Location	Land to South of Low Road/Rangell Gate (B1165) and East of A16 Spalding
Proposal	Demolition of existing buildings and construction of a new plant based protein extraction facility and ancillary office space together with landscaping, SuDs features, car park and associated infrastructure

---

Name	Steve Branson
Address	SHDC Priory Road
Date Submitted	12-10-21
For/Against	Comments

No objection.

Would request the following condition:
Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A)when measured as a 15 minute LA(eq) at any residential boundary not within the applicant's ownership.