FILE COPY

SOUTH HOLLAND DISTRICT COUNCIL

Town and Country Planning Act 1990

Planning Permission

Reference: H16/1004/98 Received:23-OCT-98 Type:FULL

Name: Anglian Water Services Ltd
PO Box 12
Lincoln
LN5 7JE

Agent: Anglian Water Services Ltd
PO Box 12
Lincoln
LN5 7JE

Description: Construct replacement sewage pumping station and new vehicle access.
Location : Plot opp. 169 Cradge Bank (TF 2347/2037) Spalding Lincs

South Holland District Council hereby give notice that PERMISSION HAS BEEN GRANTED for the development in accordance with the application and plans submitted, subject to any condition(s) set out below:

1 The development must be begun not later than the expiration of five years beginning with the date of this permission.

Reason: As required by Section 91 of the Town and Country Planning Act 1990.

2 Before any development is commenced, a scheme of landscaping and tree planting for the site, including details of positions, heights on planting and species of trees and shrubs, shall be submitted to and approved in writing by the Local Planning Authority.

Reason: In the interests of visual amenity.

3 The approved scheme of landscaping and/or screening shall be carried out in its entirety within a period of two years beginning with the date on which development of the land is commenced. The trees, shrubs or bushes shall be adequately maintained by the owner(s) of the land on which they are situated for a period of ten years beginning with the date of completion of the scheme, and all losses shall be made good during that period.

Reason: In the interests of visual amenity and to ensure that the approved scheme is implemented satisfactorily.

4 Noise from fixed plant and machinery should not exceed a level equivalent to 30 dB LA eq 5 minutes as measured at a height of 1.5 metres and 3.5 metres from any residential facade between the hours of 23.00 and 0700 on the following day.

Reason: In the interests of residential amenity.

SALLY WALTHAM BA (Hons) F.C.I.H. Director of Housing & Planning Services

Housing & Planning Services Department, Council Offices, Priory Road, Spalding, Lincolnshire. PE11 2XE (Tel: 01775 761161)

SOUTH HOLLAND DISTRICT COUNCIL

Director of Housing and Planning Services
24-NOV-98 H16/1004/98

This decision refers only to that required for the purposes of the Town and Country Planning Act and not for Building Regulations or any other legislation. See enclosed notes relating to rights of appeal.

SALLY WALTHAM BA (Hons) F.C.I.H. Director of Housing & Planning Services

Housing & Planning Services Department, Council Offices, Priory Road, Spalding, Lincolnshire. PE11 2XE (Tel: 01775 761161)

Town and Country Planning Act etc

DRAFT PERMISSION

Reference: H16/1004/98 Received:23-OCT-98 Type:FULL

Name: Anglian Water Services Ltd
PO Box 12
Lincoln
LN5 7JE

Agent: Anglian Water Services Ltd
PO Box 12
Lincoln
LN5 7JE

Description: Construct replacement sewage pumping station and new vehicle access.
Location : Plot opp. 169 Cradge Bank (TF 2347/2037) Spalding Lincs

South Holland District Council hereby give notice that permission has been granted (or equiv) on the following condition(s):

1 The development must be begun not later than the expiration of five years beginning with the date of this permission.

Reason: As required by Section 91 of the Town and Country Planning Act 1990.

2 Before any development is commenced, a scheme of landscaping and tree planting for the site, including details of positions, heights on planting and species of trees and shrubs, shall be submitted to and approved in writing by the Local Planning Authority.

Reason: In the interests of visual amenity.

3 The approved scheme of landscaping and/or screening shall be carried out in its entirety within a period of two years beginning with the date on which development of the land is commenced. The trees, shrubs or bushes shall be adequately maintained by the owner(s) of the land on which they are situated for a period of ten years beginning with the date of completion of the scheme, and all losses shall be made good during that period.

Reason: In the interests of visual amenity and to ensure that the approved scheme is implemented satisfactorily.

4 Noise from fixed plant and machinery should not exceed a level equivalent to 30dB LA eq 5 minutes as measured at a height of 1.5 metres and 3.5 metres from any residential facade between the hours of 23.00 and 0700 on the following day.

Reason: In the interests of residential amenity.

20-NOV-98

Checked 16.23/11

Authorised to issue (inc Delegation)..DR 24/11..