

Online Comment

Application H16-1045-21
Location 17 Winsover Road Spalding PE11 1EG
Proposal Installation of wall mounted air conditioner units - retrospective

Name Steve Branson
Address SHDC Priory Road

Date Submitted 19-10-21
For/Against Comments

No objection but would to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicants ownership.