Online Comment

Application	H16-1095-18
Location	15 STENNETT AVENUE SPALDING PE11 3AX
Proposal	Erection of one bed affordable dwelling

Name	Sue Armour
Address	Environmental Protection Officer SHDC
Date Submitted	03-12-18
For/Against	Comments

I request the following condition:
a)Investigate the site for landfill gas to the satisfaction of the LPA, to ascertain whether gas protection measures are required. Where measures are required the details shall be submitted to, and approved by, the LPA.
OR
b)The applicant shall install gas protection measures as a precautionary measure without first investigating the site. The details of these measures shall be submitted to, and approved by, the LPA.

c) For a) and b) all required measures shall be installed before the development is first occupied.