



Noise Impact Assessment

Site Address: Naylor Farms, Rangell Gate, Spalding, Lincolnshire

Client Name: Naylor Farms

Project Reference No: NP-010699



Authorisation and Version Control

Revision	Reported By	Checked By
01	C. Hawkins-Smith, MIOA	M. Caley, MSc, MIOA

Amendment History

Revision	Date	Summary of Amendments
01	28/05/2024	--

Disclaimer

This document has been prepared for the Client only and solely for the purposes expressly defined herein. NOVA Acoustics Ltd owe no duty of care to any third parties in respect of its content. Therefore, unless expressly agreed by NOVA Acoustics Ltd in signed writing, NOVA Acoustics Ltd hereby exclude all liability to third parties, including liability for negligence, save only for liabilities that cannot be so excluded by operation of applicable law. This report has been solely based on the specific design assumptions and criteria stated herein.

All works undertaken by NOVA Acoustics Ltd are carried out in accordance with NOVA Acoustics Ltd's terms and conditions found at www.novaacoustics.co.uk.

Contact Details

NOVA Acoustics Ltd,
Suite 13, Crown House,
94 Armley Road,
Leeds,
LS12 2EJ

0113 322 7977

www.novaacoustics.co.uk
technical@novaacoustics.co.uk

Delivering sustainable development by promoting good health and well-being through effective management of noise.

Contents

1.	INTRODUCTION	4
1.1	Standards, Legislation, Policy & Guidance	4
1.2	Proposal Brief	4
1.3	Local Planning Authority	5
2.	ENVIRONMENTAL NOISE SURVEY	7
2.1	Measurement Methodology	7
2.2	Context & Subjective Impression.....	8
2.3	Environmental Noise Survey Results.....	8
3.	NOISE IMPACT ASSESSMENT	10
3.1	Specific Sound Levels & Plant Assumptions	10
3.2	Processes and Machinery Under Assessment	10
3.3	External Fixed Plant.....	10
3.4	Internal Noise Breakout.....	13
3.5	Mobile Plant.....	15
3.6	Noise Modelling Data.....	15
3.7	BS4142 Noise Impact Assessment	18
3.8	Recommendations and Best Practicable Means.....	19
4.	RATING LEVEL LIMITS	20
5.	CONCLUSION AND ACTION PLAN	21
	APPENDIX A – ACOUSTIC TERMINOLOGY	22
	APPENDIX B – STANDARDS, LEGISLATION, POLICY, AND GUIDANCE	23
	B.1 – National Planning Policy Framework (2023).....	23
	B.2 – Noise Policy Statement for England (2010).....	23
	B.3 – BS4142:2014+A1:2019 – ‘Methods for rating and assessing industrial and commercial sound’	24
	APPENDIX C – ENVIRONMENTAL SURVEY	28
	C.1 – Time History Noise Data	28
	C.2 – Surveying Equipment	28
	C.3 – Meteorological Conditions	28

List of Figures

<i>Figure 1 – Site Layout Plan of Proposed Development.....</i>	<i>5</i>
<i>Figure 2 – Measurement Locations and Site Surroundings.....</i>	<i>7</i>
<i>Figure 3 – MP1 Operational Hours Background Sound Level Analysis – Daytime</i>	<i>9</i>
<i>Figure 4 – MP1 Operational Hours Background Sound Level Analysis – Night-time</i>	<i>9</i>
<i>Figure 5 – Assumed Plant Locations.....</i>	<i>14</i>
<i>Figure 6 – Daytime Specific Sound Level Map – 1.5 Grid Map Height – 2D</i>	<i>16</i>
<i>Figure 7 – Daytime Specific Sound Level Map – 1.5 Grid Map Height – 3D</i>	<i>16</i>
<i>Figure 8 – Night-time Specific Sound Level Map – 1.5 Grid Map Height – 2D</i>	<i>17</i>
<i>Figure 9 – Night-time Specific Sound Level Map – 1.5 Grid Map Height – 3D</i>	<i>17</i>
<i>Figure 10 – MP1 Noise Survey Time History.....</i>	<i>28</i>

List of Tables

<i>Table 1 – Measurement Methodology</i>	<i>7</i>
<i>Table 2 – Noise Sensitive Receptor Locations</i>	<i>8</i>
<i>Table 3 – Sound Pressure Levels of Noise Generating Equipment</i>	<i>11</i>
<i>Table 4 – Sound Power Levels of Noise Generating Fixed Plant</i>	<i>13</i>
<i>Table 5 – HGV Sound Power Levels</i>	<i>15</i>
<i>Table 6 – BS4142 Noise Impact Assessment.....</i>	<i>18</i>
<i>Table 7 – Rating Level Limits</i>	<i>20</i>
<i>Table 8 – Surveying Equipment.....</i>	<i>28</i>
<i>Table 9 – Weather Conditions.....</i>	<i>29</i>

1. Introduction

NOVA Acoustics Ltd has been commissioned to prepare a noise impact assessment for a new anaerobic digestion site ('the proposed development') on vacant land east off the A16, Spalding, Lincolnshire ('the site'). The anaerobic digestion ('AD') plant shall support the plant-protein extraction factory already under construction occupying the land immediately north of the proposed development site, although shall not form part of the existing site and should be considered as its own entity.

The client is preparing to submit a planning application to the Local Planning Authority ('LPA'), South Holland District Council. This report is to form part of the overall application and provides supplementary technical information regarding the site's suitability for the proposed use.

A noise survey has been undertaken to establish the prevailing background sound levels at the closest Noise Sensitive Receptors ('NSRs'). The report details the existing background sound climate and the noise emissions associated with the site to establish what impact, if any, is expected at the surrounding NSRs. Measures required to mitigate noise impact have been recommended where necessary and assessed in accordance with the relevant performance standards, legislation, policy and guidance.

This noise assessment is necessarily technical in nature; therefore, a glossary of terms is included in Appendix A to assist the reader.

1.1 Standards, Legislation, Policy & Guidance

The following performance standards, legislation, policy and guidance have been considered to ensure good acoustic design in the assessment:

- National Planning Policy Framework (2023)
- Noise Policy Statement for England (2010)
- BS4142:2014+A1:2019 – 'Methods for rating and assessing commercial and industrial sound'
- British Standard BS5228:2009+A1:2014 – 'Code of practice for noise and vibration control on construction and open sites'

Further information on the legislation can be found in Appendix B.

1.2 Proposal Brief

The proposal is for a new AD site including all associated AD plant, a digestate processing building and a waste transfer building. The plant shall extract plant-based proteins from cabbages, which shall then be used by the new Naylor Nutrition premises immediately north of the proposed development. It should be noted that the Naylor Nutrition Factory is a separate development despite it being operated and owned by the same business. At present, the vacant land is being used agriculturally to grow cabbages.

It is understood that the majority of plant will be operational 24/7, although no mobile plant or HGV deliveries shall take place outside of daytime hours (07:00 – 23:00).

Figure 1 overleaf shows a site layout plan of the proposed development.




Figure 1 – Site Layout Plan of Proposed Development

1.3 Local Planning Authority

The LPA has combined with nearby councils Boston Borough Council and Lincolnshire County Council to form the South East Lincolnshire Joint Strategic Planning Committee, which is responsible for the Local Plan for the area. The South East Lincolnshire Local Plan 2011-2036, adopted in March 2019, has been consulted and any policies applicable to the site have been reproduced on the overleaf. For conciseness, any large portions of text within the policy not applicable to noise have been removed.

“Policy 2: Development Management

Proposals requiring planning permissions for development will be permitted to provided that sustainable development considerations are met, specifically in relation to:

[...]

6. impact upon neighbouring land uses by reason of noise, odour, disturbance or visual intrusion;

[...]”

And

“Policy 30: Pollution

Development proposals will not be permitted where, taking account of any proposed mitigation measures, they would lead to unacceptable adverse impacts upon:

1. health and safety to the public;

2. the amenities of the area; or
3. the natural, historic and built environment;

By way of:

4. air quality, including fumes and odour;
5. noise including vibration

[...]"

In addition to the above policies, it is noted that the following conditions were issued to the neighbouring plant-protein factory in relation to plant noise emissions. Whilst the proposed development includes significantly more items of fixed plant, the condition still provides insight as to what the LPA deem to be acceptable within the local area.

"Condition 7 – Noise from fixed plant and machinery shall not exceed a level of 5 dB(A) above the background noise level when measured as an L(A)_{eq15min} at any residential boundary not within the applicant's ownership.

Reason: To ensure that there is no noise nuisance to nearby residents. This Condition is imposed in accordance with Policies 2, 3 and 30 of the South East Lincolnshire Local Plan, 2019."

And

"Condition 8 – The following noise mitigation measures shall be exercised in addition to Condition 7 above:

- *No static refrigerated trailer units shall be operated on the site;*
- *Refrigeration units on vehicles shall be turned off when such vehicles are stationary; and*
- *Delivery/dispatch vehicle engines shall not be left running whilst stationary*

Reason: To safeguard the amenities of nearby dwellings. This Condition is imposed in accordance with Policies 2, 3 and 30 of the South East Lincolnshire Local Plan, 2019".

Despite the LPA deeming a specific level up to 5 dB above the existing background level to be acceptable, this assessment has targeted a cumulative plant rating level not exceeding the existing background sound level, based on the proposed development only. The reason for the more onerous criteria is to prevent gradual noise creep within what is already a relatively quiet and rural area.

2. Environmental Noise Survey


2.1 Measurement Methodology

A previous environmental noise survey was conducted less than three years ago for the adjacent site; the existing measured sound levels are still thought to be valid and representative. The details of the environmental noise survey are taken directly from NOVA Acoustics report 6470PI, with the following table outlining the measurement dates and particulars.

Location	Survey Dates	Measurement Particulars
MP1	11/08/21 – 12/08/21	Equipment affixed to a telegraph post where Rangell Gate meets Fulney Lane South. A measurement height approximately 4.5m above local ground was used to avoid interference by the general public. Measurement position representative of the first-floor window of the surrounding NSRs.

Table 1 – Measurement Methodology

The figure below outlines the site surroundings and measurement location:



Imagery ©2023 Infoterra Ltd & Bluesky, Maxar Technologies, The GeoInformation Group, Map data ©2023

Figure 2 – Measurement Locations and Site Surroundings

2.2 Context & Subjective Impression

The site is currently used for agricultural purposes and is situated within a semi-rural area to the east of the main town of Spalding. The surrounding area is mixed in nature with land uses including sporadic residential, agricultural farmland and agriculturally based industrial buildings. Spanning the entire eastern and western boundaries of the site are the A16 and Rangell Gate respectively, with the A16 noted to support relatively higher traffic volumes.

To the east is a collection of allotments, farmland, and a large garden centre / plant warehouse. To the immediate south is another cabbage field which is understood to be farmed by Naylor Farms and is associated with the development. Further to the south is the commercial / industrial site operated by David Bowman Ltd, who specialise in the wholesale and distribution of pumpkins. To the west is another large greenhouse which is understood to be a plant nursery, known as 'Water Lane Nurseries'.

Overall, the acoustic environment is described as being moderate in level with the A16 and Rangell Gate providing constant traffic noise. During the site visits it was noted that the other surrounding roads are used frequently for farm vehicles and commercial traffic.

A number of noise sensitive receptors have been identified within proximity to the site, with the closest dwellings illustrated in Figure 2 on the previous page. Due to the quantity of houses and the differing directions, the table below details the names of the properties and the approximate distances from the NSRs to the site boundary.

Identifier	Addresses	Approximate distance
NSR1	'Graewin', 'Modena' and 'Riomar' off Low Road	132m
NSR2	'Cottage Farm' off Low Road	142m
NSR3	'Four Winds', 'Denva House' and 'La Notre' off Fulney Road South	170m
NSR4	'Bramble Lodge' off Rangell Gate	40m

Table 2 – Noise Sensitive Receptor Locations

2.3 Environmental Noise Survey Results

Background Sound Level Analysis

The following section outlines the measured background sound levels that have been used as the baselines for the subsequent BS4142 noise assessments. The figures on the overleaf present histogram graphs of the background sound levels measured throughout the entire survey period. The results have been separated into the respective daytime and night-time assessment periods, in line with BS4142.. The complete time history results can be found in Appendix D.




Figure 3 – MP1 Operational Hours Background Sound Level Analysis – Daytime

As can be seen in the figure above, the statistically most repeated background sound level during the daytime was 63 dBA. However, considering the location of this value within the range, a background noise level of **58 dBA** is thought to be more appropriate due to median siting.




Figure 4 – MP1 Operational Hours Background Sound Level Analysis – Night-time

Considering the range and distribution of values during the night-time period, **43 dBA** has been used as the representative background sound level during the night. Not only is this level the modal value, but it is also positioned towards the lower end of the scale and is by nature conservative.

3. Noise Impact Assessment

3.1 Specific Sound Levels & Plant Assumptions

Due to the bespoke nature of the equipment being installed, acoustic test data for separate plant elements is not readily available. However, noise data for the plant has been provided by the applicant's M&E designer, with these levels being used to inform the subsequent assessment. It must be noted that the data has the following limitations:

- No octave band spectral values have been provided. All values are single figure 'global' A-weighted levels only.
- No plant dimensions are provided, and all values are given as sound pressure levels measured at varying distances of 1-2m.
- The raw test data has not been provided, as such, the measurement procedures and equipment specifications are unknown.

Given the limitations shown above, the following assessment is **exclusively indicative in nature**. It is intended to be utilised to assess whether the site is likely to be suitable for the proposed use, but is in no way definitive. It is recommended that further assessment is undertaken during the detailed design phase. Further advice is provided in Section 5.

3.2 Processes and Machinery Under Assessment

The main noise generating elements are thought to be as follows:

External Fixed Plant

- This includes various pumps, mixers, gas processing and mixing, power generation, etc.

Internal Noise Breakout

- This includes noise breakout from within the digestate processing and waste processing buildings.

External Mobile Plant

- This is likely to include noise from HGVs and effluent tankers.

The applicant has stated that all noise from input hoppers being loaded, etc. will take place within the digestate processing building, and the material will then be transported around the using pipework. As such, wheeled loaders and forklift trucks will not be operated in the external areas.

3.3 External Fixed Plant

The table contains details of the external plant understood to be included within the development, as provided by the M&E designer.

Plant Name	Quantity	Sound Level Provided (L _{Aeq} , dB)	Measurement Distance	Total Sound Pressure Level at 1m (dB)
CHP	1	113	1m	113
Oxygen Purification	1	66 [1]	--	58
Methane Upgrader	1	85	1m	85
Feed Pump	2	80	1m	83
Heating & Recirculating Pump	3	80	1m	85
Effluent Pump	1	80	1m	80
Thin Fraction Pump	1	80	1m	80
Spiral Mixer [2]	2 per digester / 8 in total	70	2m	85
Spiral Mixer [2]	1 per storage tank / 8 in total	70	2m	85
Roof Blower	12	73	1.5m	87
Flare	1	79	15m	103

Notes:

[1] No distance provided therefore the level is assumed to be a sound power level.

[2] As two different levels were provided for the spiral mixers, the levels with 'sound protection' present have been used.

Table 3 – Sound Pressure Levels of Noise Generating Equipment

Sound power levels for each item of plant are calculated considering the following parameters:

Spiral Mixers

- 15kW spiral mixers are used to constantly mix the material contained in the digestors and storage silos. These are expected to act as point source noise emitters at a distance of 1m. A example product is the 'Landia POP-I Submersible Mixer 15kW', the motor for which has a housing with a maximum length of 1.2m, which suggests point source propagation at 1m. Mixers are also located within the digesters and silos; however, they will be fully submersed in material, and as such, are expected to be inaudible.
- It should be noted that sound levels were provided with and without sound protection present. The sound protection configuration must be installed to reduce noise emissions, allowing for the lower of the two values provided to be used within the assessment.

Pumps

- Noise emissions from pumps used for feeding the biogas plant, such as lobe pumps and progressive cavity pumps, are also thought to be exhibiting point source propagation at 1m due to their relatively small dimensions. An example of this is the 'LOBEPRO M100' rotary pump, which has a maximum length of 0.7m.

CHP Unit and Oxygen Purification Generator

- The combined heat and power gas engine is used to generate electricity using the biogas produced on site. The oxygen purification generator is expected to comprise of various processes that remove hydrogen sulphide from the anaerobic digesters. The sound power levels of the CHP unit and oxygen purification generator are calculated considering the total surface area of each section, using the formula: $L_{WA} = L_{PA} \text{ at } 1m + 10 \log (S)$.
- The CHP unit must be housed in an enclosure capable of reducing noise emissions by a minimum of **45 dB**. It is thought that this can be achieved with a 100mm enclosure such as the 'WA-ACP-A100S' from Wakefield Acoustics or a bespoke product from the manufacturer of the CHP. Further assessment will be required when octave band data is available.

Methane Upgrader

- The job of the methane upgrader is to reduce levels of CO₂ in the system whilst increasing the quality of the methane. The majority of the sound emitted from the methane upgrader is thought to come from the gas compression motor. An example unit is the 'Meidinger AG / AHA/ 125/1020/1 G', which also emits a sound pressure level of **85 dBA** at 1m. As such, this is considered to be exhibit point source behaviour at 1m.

CO₂ Liquefaction System

- The purpose of this system is to improve the carbon intensity (CI) score by recovering and liquefying the CO₂ from the biogas upgrading process. It is assumed that this process is not noise generating as noise emission data has not been provided.

Flare

- A standby gas flare will be situated to the southwestern section of the external plant area. This is typically expected to operate when the CHP is in shutdown for servicing or in case of emergency. As such, it is expected to be used very rarely. To provide a robust assessment a 10% on-time correction will be applied. However, it has been stated by the applicant that noise emissions could reach 79 dBA at 15m, which equates to a sound power level of 111 dBA. In order to avoid adverse impact, it is recommended that this is attenuated to a sound pressure level not exceeding **80 dBA** at 1m.

Roof Blowers

- The roofs of the digesters and silos are constructed from inflatable double membrane systems. In order to maintain a stable pressure, roof blowers are installed which operate during drops in pressure. The noise generating element of a roof blower is thought to be an externally mounted motor. The applicant has provided a range of noise emission values of 73 – 91 dBA at 1.5m. In order to avoid adverse impact, it is recommended that the lower value of **73 dBA** is achieved. This equates to a sound power level of **85 dBA** per blower. Again, it is expected that the blowers will be used rarely, however, to provide a robust assessment a 10% on-time correction will be applied.

Sound Power Level Calculations

Considering the parameters above, the sound power levels are predicted in the following table. All values are calculated assuming that sound pressure levels were measured against one reflective surface (giving a Q factor of 2).

Plant Name	Quantity	Sound Pressure Level at 1m Per Unit (dBA)	Predicted Sound Power Level Per Unit (dBA)	Total Sound Power Level (dBA)
CHP	1	68 [1]	88 [1]	91 [1]
Oxygen Purification	1	58	76	76
Methane Upgrader	1	85	93	93
Feed Pump	2	80	88	91
Heating & Recirculating Pump	3	80	88	93
Effluent Pump	1	80	88	88
Thin Fraction Pump	1	80	88	88
Spiral Mixer	2 per digester / 8 in total.	76	84	93
Spiral Mixer	1 per storage tank / 8 in total.	76	84	93
Roof Blower	9	77	75 [2]	85 [2]
Flare	1	80 [3]	78 [2, 3]	78 [2, 3]
Cumulative Sound Power Level for All External Fixed Plant				101
Notes: [1] CHP noise emissions with enclosure. [2] 10% on-time correction applied (-10 dB). [3] Attenuated level.				

Table 4 – Sound Power Levels of Noise Generating Fixed Plant

3.4 Internal Noise Breakout

Internal plant is to be located within the digestate processing building and waste transfer building. Further to this, loading and unloading activities are expected to take place within the waste transfer and digestate processing buildings. The predicted noise levels within the buildings are as follows:

Digestate and Waste Transfer

The location and extent of the plant and activities could not be accurately determined by the M&E designer at this stage, however, considering the usage of the buildings, the following parameters have been used in the calculations:

- From previous experience, ambient noise levels in warehouse areas, where the primary source of noise is forklift loading / unloading, are unlikely to exceed **80 dBA**. Noise will not be generated during the night-time period.

Building Constructions and Calculation Parameters

- The building envelopes will be constructed from composite panels, similar to Kingspan KS1000 panels, providing a sound reduction of approximately 25 dB R_w . Rooms will be created within the buildings, giving a total sound reduction **40 dB R_w** .
- A diffusivity (C_d) correction of -3 dB is applied as per ISO 9613-2.
- It is assumed that roller shutter doors located on the southern façades of the digestate / waste transfer buildings will be frequently opened to allow for HGV access. As such, to present a worst-case scenario, these are modelled as constantly open during the daytime.

Fixed Plant for Buildings

NOVA Acoustics have been informed that air purification systems will be installed within the digestate processing and waste transfer buildings which will vent externally. The systems will comprise of scrubbers and carbon filters which will vent to the external atmosphere. It is stated in the manufacturer's literature that noise at the external vents for these systems will not exceed **69 dBA** at 1m. No duct lengths, duct dimensions, spectral data or specific locations are available at this stage. Further to this, 'Centrair Solution' fans will also be included, which operate at **72 dBA** at 1m. These have been modelled on the worst-case façades of both buildings. The odour abatement system is assumed to be located internally however, should this not be the case, the assessment must be updated accordingly.

Internally, noise from the fixed plant within the buildings is not expected to exceed **69 dBA**, which is negligible when considering the sound reduction provided by the building envelopes.

The assumed fixed plant locations and heights are shown in the figure below. The yellow stars represent the locations of the roof blower motors (positioned at ground level).




Figure 5 – Assumed Plant Locations

3.5 Mobile Plant

HGVs will access the site six days a week for deliveries and will be limited to daytime hours only, although the number of HGVs is unknown. For the purpose of this assessment, it is assumed that HGVs and effluent tankers will be traversing the site for a maximum of 20% of the time, equating to 12 minutes per hour. According to the plans provided, all loading and unloading will take place internally and as such is not expected to contribute to the assessment outcome.

The table below shows the sound power level used to represent HGVs in the noise model.

Plant Name	Source Reference	Uncorrected L _{WA} (dB)	On-time Correction (dB)	L _w Including Correction (dBA)
HGV or Effluent Tanker in Motion	Table C.11, Ref no. 13	106	-7 ^[1]	99
Notes [1] An on-time correction is to allow for 20% movement time.				

Table 5 – HGV Sound Power Levels

3.6 Noise Modelling Data

The noise generating equipment and processes defined in the previous section have been modelled within SoundPlan 9.0 prediction software.

The following assumptions have been made within the software:

- To accurately model the land surrounding the Proposed Development, the topographical data has been obtained from the EA's 'National LIDAR Programme' on the DEFRA Data Services Platform.
- For the purpose of the assessment, the ground between the source and receivers is considered to be primarily acoustically 'soft' surfaces.
- ISO 9613-2 assumes a 'downwind' model to the NSRs.
- The sound map grid height has been set to 1.5m, however, the noise levels used in the assessment has been taken from the most exposed point of each façade.
- The proposed development has been modelled in accordance with Figure 5 and using the source levels in Table 4.
- Point source emitters have been used to represent all noise sources under assessment. Each source has been modelled at the heights specified in Figure 5.
- To provide a 'robust' assessment, all noise sources are assumed to operate continuously.
- All roller shutters will remain closed during the night-time operational periods, providing a minimum sound reduction of 20 dB R_w.

The elevation drawings provided indicate that a 6m earth bund with planted landscaping on top shall enclose the majority of the site. This bund has been included within the noise mode, as shown in Figures 7 and 9; however, should the bund contain no solid earth element then the calculations and report will need to be updated.

The sound maps showing the specific sound levels emission from the site can be seen in the following figures.




Figure 6 – Daytime Specific Sound Level Map – 1.5 Grid Map Height – 2D




Figure 7 – Daytime Specific Sound Level Map – 1.5 Grid Map Height – 3D




Figure 8 – Night-time Specific Sound Level Map – 1.5 Grid Map Height – 2D




Figure 9 – Night-time Specific Sound Level Map – 1.5 Grid Map Height – 3D

3.7 BS4142 Noise Impact Assessment

The BS4142 noise impact assessments are conducted at the most affected NSRs in the table below. During the daytime, the highest specific noise levels are expected to be experienced at 'Bramble Lodge' (NSR4) and during the night, the highest levels are expected at 'Cottage Farm' (NSR2).

Noise Impact Assessment at NSR4 – Daytime		
Description	Comments and Explanation	Overall (dBA)
Specific Sound Level at NSR4 (L_{eq})	Cumulative noise levels from the site.	42
Acoustic Feature Correction	A +2 dB penalty is applied for a ‘just perceptible’ tonality as spectral content of the plant is unknown. A +3 dB penalty is applied for intermittency as multiple items of plant will operate intermittently.	+5
Rating Sound Level ($L_{Ar,T}$)	Specific sound level plus rating penalties.	47
Background Sound Level (MP1 – L_{A90})	Lowest typical background ($L_{A90,15min}$) at MP1 during the daytime.	58
Exceedance of L_{A90}	Exceedance of rating level above background.	-11
BS4142 Assessment Outcome	‘Low Impact, dependent on context’.	
NPPF & NPSE Outcome	‘No Observed Effect Level (‘NOEL’).	
No further mitigation measures are deemed necessary.		
Noise Impact Assessment at NSR2 and NSR4 – Night-time		
Description	Comments and Explanation	Overall (dBA)
Specific Sound Level at NSR2 and NSR4 (L_{eq})	Cumulative noise levels from the site.	34
Acoustic Feature Correction	A +2 dB penalty is applied for a ‘just perceptible’ tonality as spectral content of the plant is unknown. A +3 dB penalty is applied for intermittency as multiple items of plant will operate intermittently.	+5
Rating Sound Level ($L_{Ar,T}$)	Specific sound level plus rating penalties.	39
Background Sound Level (MP1 – L_{A90})	Typical background measured ($L_{A90,15min}$) at MP1 during the night.	43
Exceedance of L_{A90}	Exceedance of rating level above background.	-4
BS4142 Assessment Outcome	‘Low Impact, dependent on context’.	
NPPF & NPSE Outcome	‘No Observed Effect Level (‘NOEL’).	
No further mitigation measures are deemed necessary.		

Table 6 – BS4142 Noise Impact Assessment

As can be seen in the table above, the rating noise levels are not expected to exceed the background noise level. This is classed as 'No Observed Effect Level' ('NOEL') when assessed with the NPPF and NPSE.

3.8 Recommendations and Best Practicable Means

It is imperative that the site should operate with best practicable means in mind. In line with good acoustic practices, it is recommended that the following procedures are enforced:

- All HGVs should be courteous to the surrounding neighbours and abide to on-site speed restrictions. Use of horns should be prohibited unless required for safety purposes.
- All mobile plant and fixed plant should be turned off when not in use. HGVs should be discouraged from waiting outside nearby residential properties and not left in idle during loading or unloading.
- The use of mobile plant should be strictly prohibited during the night-time period (between 23:00 and 07:00 hours).
- All plant should be routinely serviced and maintained to ensure it is operating at optimal efficiency.
- Plant should be placed sympathetically to the surrounding NSRs with a direct line of sight to fixed plant and ductwork terminations avoided wherever possible.
- Shouting and external radios should be discouraged given the proximity to the nearby farms.
- All façade openings to internally noisy areas should remain closed when in use whenever possible, including any windows, roller shutter doors or other façade openings.
- Should any heavy or mobile plant be required for the proposed recycling centre should be assessed separately to ensure that no adverse impact is anticipated at the surrounding NSRs.

4. Rating Level Limits

Given the level of uncertainty present within this assessment and its speculative nature, fixed plant rating level limits have been defined to ensure that any future plant or plant not included as part of this assessment does not result in unacceptable noise levels at the surrounding NSRs.

The rating levels should be determined 1m from most exposed façade of the nearest NSRs and should not exceed the limits outlined in the table below. Note that these limit levels are inclusive of any rating penalties that should be applied to account for increased levels of subjective annoyance, due to factors such as impulsivity, tonality, etc.

Period	Background Sound Levels ($L_{A90,T}$ dB)	Rating Level Limit ($L_{A,r,Tr}$ dB)
Daytime (07:00 – 23:00)	58	48
Night-time (23:00 – 07:00)	43	33

Table 7 – Rating Level Limits

5. Conclusion and Action Plan

The proposed development has been assessed against the requirements of BS4142 and the LPA's policies and guidance.

In order to achieve a low likelihood of adverse impact, the following mitigation should be implemented:

- All buildings must provide a minimum sound reduction of **40 dB R_w**.
- The CHP units must be housed in enclosures capable of reducing noise emissions by a minimum of **45 dB**. It is thought that this can be achieved with a 100mm enclosure such as the 'WA-ACP-A100S' from Wakefield Acoustics or a bespoke product from the manufacturer of the CHP.
- Noise from the flare must be reduced to a maximum of **80 dBA** at 1m.
- The 'Best Practicable Means' defined in Section 3.8 must be adhered to.

Considering the number of inherent limitations detailed in Section 3.1, this assessment is **exclusively indicative in nature**. It is intended to be utilised to assess whether the site is likely to be suitable for the proposed use but is in no way definitive. For this reason, it is recommended that further assessment is undertaken during the detailed design phase, which should include a full octave band analysis. If this is not possible, and planning permission is granted, it is instead recommended that a validation testing condition is imposed by the Local Authority. It should be noted that if any further mitigation is required due to the results of the validation testing this is likely to be onerous and costly for the applicant.

Appendix A – Acoustic Terminology

A-weighted sound pressure level, L_{pA}	Quantity of A-weighted sound pressure given by the following formula in decibels (dBA). $L_{pA} = 10 \log_{10} (pA/p_0)^2$. Where: pA is the A-weighted sound pressure in pascals (Pa) and p_0 is the reference sound pressure (20 μ Pa)
Background Sound	Underlying level of sound over a period, T , which might in part be an indication of relative quietness at a given location
Equivalent continuous A-weighted sound pressure level, $L_{Aeq,T}$	Value of the A-weighted sound pressure level in decibels (dB) of a continuous, steady sound that, within a specified time interval, T , has the same mean-squared sound pressure as the sound under consideration that varies with time
Facade level	Sound pressure level 1 m in front of the facade
Free-field level	Sound pressure level away from reflecting surfaces
Indoor ambient noise	Noise in a given situation at a given time, usually composed of noise from many sources, inside and outside the building, but excluding noise from activities of the occupants
Noise Criteria	Numerical indices used to define design goals in a given space
Noise Rating (NR)	Graphical method for rating a noise by comparing the noise spectrum with a family of noise rating curves
Octave Band	Band of frequencies in which the upper limit of the band is twice the frequency of the lower limit
Percentile Level, $L_{AN,T}$	A-weighted sound pressure level obtained using time-weighting “F”, which is exceeded for $N\%$ of a specified time interval
Rating Level, $L_{Ar,Tr}$	Equivalent continuous A-weighted sound pressure level of the noise, plus any adjustment for the characteristic features of the noise
Reverberation time, T	Time that would be required for the sound pressure level to decrease by 60 dB after the sound source has stopped
Sound Pressure, p	root-mean-square value of the variation in air pressure, measured in pascals (Pa) above and below atmospheric pressure, caused by the sound
Sound Pressure Level, L_p	Quantity of sound pressure, in decibels (dB), given by the formula: $L_p = 10 \log_{10} (p/p_0)^2$. Where: p is the root-mean-square sound pressure in pascals (Pa) and p_0 is the reference sound pressure (20 μ Pa)
Weighted sound reduction index, R_w	Single-number quantity which characterizes the airborne sound insulating properties of a material or building element over a range of frequencies

Appendix B – Standards, Legislation, Policy, and Guidance

This report is to be primarily based on the following standards, legislation, policy and guidance.

B.1 – National Planning Policy Framework (2023)

Government policy on noise is set out in the National Planning Policy Framework (NPPF), published in 2023. This replaced all earlier guidance on noise and places an emphasis on sustainability. In section 15, Conserving and enhancing the natural and local environment, paragraph 180e, it states:

Preventing new and existing development from contributing to, being put at unacceptable risk from, or being adversely affected by, unacceptable levels of soil, air, water or noise pollution or land instability. Development should, wherever possible, help to improve local environmental conditions such as air and water quality, taking into account relevant information such as river basin management plans;

Paragraph 191 states:

Planning policies and decisions should also ensure that new development is appropriate for its location taking into account the likely effects (including cumulative effects) of pollution on health, living conditions and the natural environment, as well as the potential sensitivity of the site or the wider area to impacts that could arise from the development. In doing so they should:

- a) Mitigate and reduce to a minimum potential adverse impact resulting from noise from new development – and avoid noise giving rise to significant adverse impacts on health and the quality of life;*
- b) Identify and protect tranquil areas which have remained relatively undisturbed by noise and are prized for their recreational and amenity value for this reason; and*
- c) Limit the impact of light pollution from artificial light on local amenity, intrinsically dark landscapes and nature conservation.*

B.2 – Noise Policy Statement for England (2010)

Paragraph 191 of the NPPF also refers to advice on adverse effects of noise given in the Noise Policy Statement for England (NPSE). This document sets out a policy vision to:

Promote good health and a good quality of life through the effective management of noise within the context of Government policy on sustainable development.

To achieve this vision the Statement identifies the following three aims:

Through the effective management and control of environmental, neighbour and neighbourhood noise within the context of Government policy on sustainable development:

- Avoid significant adverse impacts on health and quality of life;
- Mitigate and minimise adverse impacts on health and quality of life;
- Where possible, contribute to the improvement of health and quality of life.

In achieving these aims the document introduces significance criteria as follows:

SOAEL – Significant Observed Adverse Effect Level

This is the level above which significant adverse effects on health and quality of life occur. It is stated that “significant adverse effects on health and quality of life should be avoided while also considering the guiding principles of sustainable development”.

LOAEL – Lowest Observed Adverse Effect Level

This is the level above which adverse effects on health and quality of life can be detected. It is stated that the second aim above lies somewhere between LOAEL and SOAEL and requires that: “all reasonable steps should be taken to mitigate and minimise adverse effects on health and quality of life while also considering the guiding principles of sustainable development. This does not mean that such adverse effects cannot occur.”

NOEL – No Observed Effect Level

This is the level below which no effect can be detected. In simple terms, below this level, there is no detectable effect on health and quality of life due to the noise. This can be related to the third aim above, which seeks: “where possible, positively to improve health and quality of life through the pro-active management of noise while also considering the guiding principles of sustainable development, recognising that there will be opportunities for such measures to be taken and that they will deliver potential benefits to society. The protection of quiet places and quiet times as well as the enhancement of the acoustic environment will assist with delivering this aim.”

The NPSE recognises that it is not possible to have a single objective noise-based measure that is mandatory and applicable to all sources of noise in all situations and provides no guidance as to how these criteria should be interpreted. It is clear, however, that there is no requirement to achieve noise levels where there are no observable adverse impacts but that reasonable and practicable steps to reduce adverse noise impacts should be taken in the context of sustainable development and ensure a balance between noise sensitive and the need for noise generating developments.

Any scheme of noise mitigation outlined in this report will, therefore, aim to abide by the above principles of the NPPF and NPSE whilst recognizing the constraints of the site.

B.3 – BS4142:2014+A1:2019 – ‘Methods for rating and assessing industrial and commercial sound’

Overview

BS4142:2014 sets out a method to assess the likely effect of sound from factories, industrial premises or fixed installations and sources of an industrial nature in commercial premises, on people who might be inside or outside a dwelling or premises used for residential purposes in the vicinity.

The procedure contained in BS4142:2014 for assessing the effect of sound on residential receptors is to compare the measured or predicted sound level from the source in question, the $L_{Aeq,T}$ ‘specific sound level’, immediately outside the dwelling with the $L_{A90,T}$ background sound level.

Where the sound contains a tonality, impulsivity, intermittency and other sound characteristics, then a correction depending on the grade of the aforementioned characteristics of the sound is added to the

specific sound level to obtain the $L_{A,r,Tr}$ 'rating sound level'. A correction to include the consideration of a level of uncertainty in sound measurements, data and calculations can also be applied when necessary.

Rating Penalty

Section 9 of BS4142:2014 describes how the rating sound level should be derived from the specific sound level, by deriving a rating penalty.

BS4142:2014 states:

"Certain acoustic features can increase the significance of impact over that expected from a basic comparison between the specific sound level and the background sound level. Where such features are present at the assessment location, add a character correction to the specific sound level to obtain the rating level. This can be approached in three ways:

- a) subjective method;*
- b) objective method for tonality;*
- c) reference method."*

Due to the nature of the development the subjective method has been adopted to derive the rating sound level from the specific sound level. This is discussed in Section 9.2 of BS4142:2014, which states:

"Where appropriate, establish a rating penalty for sound based on a subjective assessment of its characteristics. This would also be appropriate where a new source cannot be measured because it is only proposed at that time, but the characteristics of similar sources can subjectively be assessed. Correct the specific sound level if a tone, impulse or other characteristics occurs, or is expected to be present, for new or modified sound sources."

BS4142:2014 defines four characteristics that should be considered when deriving a rating penalty, namely; tonality; impulsivity; intermittency; and other sound characteristics, which are defined as:

a) Tonality

A rating penalty of +2 dB is applicable for a tone which is "just perceptible", +4 dB where a tone is "clearly perceptible", and +6 dB where a tone is "highly perceptible".

b) Impulsivity

A rating penalty of +3 dB is applicable for impulsivity which is "just perceptible", +6 dB where it is "clearly perceptible", and +9 dB where it is "highly perceptible".

c) Other Sound Characteristics

BS4142:2014 states that where "the specific sound features characteristics that are neither tonal nor impulsive, though otherwise are readily distance against the residual acoustic environment, a penalty of +3 dB can be applied."

d) Intermittency

BS4142:2014 states that when the "specific sound has identifiable on/off conditions, the specific sound level ought to be representative of the time period of length equal to the reference time interval which contains the greatest total amount of on time ... if the intermittency is readily distinctive against the residual acoustic environment, a penalty of +3 dB can be applied."

Background Sound Level

The background sound level is the underlying level of sound over a period, T, and is indicative of the relative quietness at a given location. It does not reflect the occurrence of transient and/or higher sound level events and is generally governed by continuous or semi-continuous sounds.

To ensure the background sound level values used within the assessment are reliable and suitably represent both the particular circumstance and periods of interest, efforts have been made to quantify a 'typical' background sound level for a given period. The purpose has not been to simply select the lowest measured value. Diurnal patterns have also been considered as they can have a major influence on background sound levels, for example, the middle of the night can be distinctly different (and potentially of lesser importance) compared to the start or end of the night time period for sleep purposes.

Since the intention is to determine a background sound level in the absence of the specific sound that is under consideration, it is necessary to understand that the background sound level can in some circumstances legitimately include industrial and/or commercial sounds that are present as separate to the specific sound.

Assessment of Impact

BS4142:2014 states: "The significance of sound of an industrial and/or commercial nature depends upon both the margin by which the rating level of the specific sound source exceeds the background sound level and the context in which the sound occurs". An estimation of the impact of the specific sound can be obtained by the difference of the rating sound level and the background sound level and considering the following:

- "Typically, the greater this difference, the greater the magnitude of the impact."
- "A difference of around +10dB or more is likely to be an indication of a significant adverse impact, depending on the context."
- "A difference of around +5dB is likely to be an indication of an adverse impact, depending on the context."
- "The lower the rating level is relative to the measured background sound level, the less likely it is that the specific sound source will have an adverse impact or a significant adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a negligible impact, depending on the context."

Interpreting the guidance given in BS4142:2014, with consideration of the guidance given in the NPSE and NPPG Noise, an estimation of the impact of the rating sound is summarised in the following text:

- A rating sound level that is +10 dB above the background sound level is likely to be an indication of a Significant Observed Adverse Effect Level;
- A rating sound level that is +5 dB above the background sound level is likely to be an indication of a Lowest Observed Adverse Effect Level;
- The lower the rating sound level is relative to the measured background sound level, the less likely it is that the specific sound source will have an adverse impact or a significant adverse impact. Where the rating sound level does not exceed the background sound level, this is an

indication of the specific sound source having a negligible impact and would therefore classified as No Observed Adverse Effect Level.

During the daytime, the assessment is carried out over a reference time period of 1-hour. The periods associated with day or night, for the purposes of the Standard, are 07.00 to 23.00 and 23.00 to 07.00, respectively.

Appendix C – Environmental Survey

C.1 – Time History Noise Data




Figure 10 – MP1 Noise Survey Time History

C.2 – Surveying Equipment

Piece of Equipment	Serial No.	Calibration Deviation
CESVA SC420 Class 1 Sound Level Meter	T250681	<0.5
CESVA CB006 Class 1 Calibrator	901927	

Table 8 – Surveying Equipment

All equipment used during the survey was field calibrated at the start and end of the measurement period with no deviation present. All sound level meters are calibrated every 24 months and all calibrators are calibrated every 12 months by a third-party calibration laboratory. All microphones were fitted with a protective windshield for the entire measurements period. Calibration certificates can be provided upon request.

C.3 – Meteorological Conditions

As the environmental noise survey was carried out over a long un-manned period no localised records of weather conditions were taken. However, all measurements have been compared with met office weather data of the area, specifically the closest weather station, and the data from the weather station is outlined in the table below. When reviewing the time history of the noise measurements, any scenarios that were considered potentially to be affected by the local weather conditions have been omitted. The analysis of the noise data includes statistical and percentile analysis and review of minimum and maximum values, which aids in the preclusion of any periods of undesirable weather conditions. The weather conditions were deemed suitable for the measurement of environmental noise in accordance with BS7445

Description and Measurement of Environmental Noise. The table below presents the average temperature, wind speed and rainfall range for each 24-hour period during the entire measurement.

Weather Conditions – Spalding – 1km West of Site				
Time Period	Air Temp (°C)	Rainfall (mm/h)	Prevailing Wind Direction	Wind Speed (m/s)
11/08/21 – 00:00 – 23:59	14.7 – 24.4	0.0	SSW	0.0 – 2.6
12/08/21 – 00:00 – 23:59	14.7 – 24.3	0.0	SSW	0.0 – 2.6

Table 9 – Weather Conditions

Rainfall occurred between 15:30 and 16:00 as a short shower and has not effected the measured noise levels.



NOVA
ACOUSTICS