

Online Comment

Application H16-1178-16
Location Goodfellows 9 Spalding Common Spalding PE11 3AS
Proposal Proposed detached bungalow

Name Noise and Contaminated Land
Address Environmental Health Technician Safety and Environment

Date Submitted 21-12-16
For/Against Comments

The site is a former brick pit and a site investigation for another property in the area concluded that there is a 'moderate' risk posed by ground gas. Therefore mitigation measures are required for the proposed property to protect the end users. I request parts 3 and 4 of the contaminated land condition for this application.