Online Comment

Application	H16-1198-16
Location	11a Spalding Common Spalding PE11 3AS
Proposal	Residential development

Name	Noise and Contaminated Land
Address	Environmental Health Technician Safety and Environment

Date Submitted	21-12-16
For/Against	Comments

A previous site investigation for this property concluded that there is a 'moderate' risk posed by ground gas at the site. Therefore mitigation measures are required in the proposed properties to protect the end users. I request parts 3 and 4 of the contaminated land condition.