Online Comment

Application	H16-1218-18
Location	Willow Walk Spalding PE11 1UX
Proposal	Residential Development of 20 Dwellings - approved under H16-0283-17. Modification of Condition 2 to allow amendments to previously approved plans and Conditions 13 and 14 relating to commencement/occupation of dwellings in conjunction with roads and footpaths

---

Name	Ruth Dowling
Address	Building Control
Date Submitted	17-01-19
For/Against	Comments

Is the road being adopted ? Rubbish should not be carried more than 30m from the dwelling and access will be required for a fire appliance.