Online Comment

Application	H16-1225-18
Location	Adj. 15 Stennett Avenue Spalding Lincs PE11 3AX
Proposal	Erection of one bed dwelling

Name	Sue Armour
Address	Environmental Protection Officer South Holland District Council
Date Submitted	08-01-19
For/Against	Comments

I request the following condition be applied to this permission:
a) i) Prior to the commencement of any development details of precautionary ground gas protection measures shall be submitted to and approved in writing by the Local Planning Authority.
ii) Prior to the first occupation, a suitably detailed ground gas verification report shall be submitted and approved in writing by the Local Planning Authority.
OR
b) the full contaminated land condition should be applied.