Gmail by Google

G R MERCHANT <grmerchant.arch.cons@gmail.com>

Vehicle Access - H17-0579-14

Ben Jackson <Ben.Jackson@lincolnshire.gov.uk> Fri, Aug 29, 2014 at 3:12 PM

To: "gr.merchant@btconnect.com" <gr.merchant@btconnect.com>
Cc: Jon Sharpe <Jon.Sharpe@lincolnshire.gov.uk>

Good Afternoon Bob,

Following on from today's telephone conversation I would like to confirm the specification for vehicle access to satisfy planning application H17-0579-14 – condition 6.

- 300mm of Lincolnshire County Council approved non-frost susceptible type 1 laid on a geo textile.
- 110mm of 20mm size recipe mix Dense Binder Course (AC 20 Dense bin 40/60 rec)
- 40mm of 10mm size Close Graded Surface Course (AC 10 close surf 70/100 or 100/150)
- The new surface course should step in to the existing carriageway by planning 300mm a width off the existing surface course and lapping the new surface course.
- The new bitmac is to be retained by bullnose kerbs (along the access's radius) with a 25mm upstand from the proposed finished access level.
- New entrance is to match the layout of the existing access.
- Install a channel kerb to delineate between the adopted and private interface
- All materials used within the highway is to be from approved suppliers.

If you have any queries please do not hesitate to contact me.

Regards

Ben Jackson EngTech TMICE

Highways Officer

Communities Directorate

Highways and Transportation

Highways South

Municipal Buildings

West Street

Boston

Lincolnshire