Planning Ref H17-1097-23
Proposed plant based protein extraction facility and anaerobic digestor plant
Land East Of Surfleet Bank And West Of Woad Farm Surfleet Spalding

P&R ARCHITECTS

Statement on Fire Fighting Strategy

As part of the drainage strategy for the site, provision of a water supply in the form of a pond providing storage for a minimum of 45,000 litres of water at all times.

Water supply for the pond will come from roof and hardstanding areas with some excess water from the processes being carried out on the site.

Clarification of this supply is provided within the Drainage strategy for the site (Page 13)

Access, space and hardstanding for fire tenders with a minimum hard standing capacity for pumping appliances of 18 tonnes will be provided around the pond a similar weight limit applied to all private/shared access roads and hardstanding around the sites.