## Gedney, Oliver

**From:** Grant, David
**Sent:** 04 February 2022 15:17
**To:** _planningadvice
**Subject:** FW: Amstel H17-1234-21

Please add this email to the DIP under 6SUP – Drainage details.

Many thanks,

**David Grant** | Senior Planning Officer | **South Holland District Council**
Direct Dial: 01775 764472
www.sholland.gov.uk
Please note that any informal officer opinion expressed by this email is without prejudice and is not binding on the Council during the consideration of any formal application.

served by One Team

---

**From:** Richards Architectural <info@richardsarchitectural.co.uk>
**Sent:** 04 February 2022 15:01
**To:** Grant, David <dgrant@sholland.gov.uk>
**Cc:** harriet@richardsarchitectural.co.uk; richard@richardsarchitectural.co.uk
**Subject:** Re: Amstel H17-1234-21

**This message originated from outside your organization**

---

Dear David,

Further to the comments from IDB, the foul water will connect to existing.
The surface water will connect to existing soakaway, if the soakaway is less than 5m from the dwelling a new soakaway will be installed in accordance with H1 of Building Regulations.

Best wishes
Nikki Chamberlain

Austin John Ltd
T/A Richards Architectural

www.richardsarchitectural.co.uk

01775 713 812
07939 000 388

4 - 6 Bear Lane
Pinchbeck

Spalding
PE11 3XA