Mr Liam Nevins
Arcus Consultancy Services Ltd
1c Swinegate Court East
York
YO1 8AJ

Our ref: AN/2024/135197/03-L01

Date: 19 March 2024

Dear Mr Nevins

Follow up response for the meeting to discuss design for proposed solar farm at Sutton Bridge
Sutton Bridge

Thank you for submitting the additional information relating to the Sutton Bridge Solar Farm.

From our conversation, you advised that the flood resilience measures for the substation (approved under H18-1126-20) are to be amended and battery storage area will be introduced.

As the development of a solar farm was approved just south of the site (planning application 21/01442/FM), and you have advised that the development would be considered less vulnerable rather than essential infrastructure, we would be willing to accept the same approach for this development whereby mitigation is set according to the 2115 0.5% tidal flood depths.

Please note that the flood risk assessment should acknowledge the risks associated by reducing the design standard of the flood resilience measures.

Should you require any additional information, or wish to discuss these matters further, please do not hesitate to contact me using the details below.

Yours sincerely

Amelia Crawford
Sustainable Places Planning Advisor
☎ 07387 134115 (mobile)
amelia.crawford@environment-agency.gov.uk
www.gov.uk/environment-agency

End