


END ELEVATION

END ELEVATION




LIMITATIONS.
This drawing is limited in the amount of information contained and does not purport to contain a full specification of the works. It is solely for the purpose of obtaining Building Regulation approval.
The drawing must not be used as a contract document alone.
All dimensions shall be taken from site from actual work. Under no circumstances shall measurements be scaled from this drawing for construction or ordering purposes.
All given dimensions shall be checked by the Builder/Contractor and will be his responsibility from commencement of site works.
The works will not be supervised or inspected on site by C.A.D. or any representative thereof. It is the client or their appointed agents responsibility to control workmanship, substitution of materials, adherence to specification, variations to contract etc.


STANDARDS.
All materials to be new unless otherwise stated and all components and materials etc. to be used fitted and installed etc. in strict accordance with manufacturers instruction and relevant Code of Practice.
Materials shall conform to appropriate British Standard Specification or BBA Certificate or European Code equivalent.

HEALTH & SAFETY.
The Employer/Client shall ensure that the selected contractor is conversant with and adopts all measures necessary to achieve compliance with Health & Safety legislation for Building Sites and Work Places.
The Employer /Client is advised that should the works need to comply with the Construction Design and Management Regulations an independant Planning Supervisor will be required.


SCOPE OF THE WORKS.
The works shall comprise of all that is shown on the drawing and details. Work that may not be specifically shown but may be reasonably inferred as necessary to carry out the works shall be deemed to be included.



Location Plan 1:2500




Block Plan 1:500



PLAN.

ROOF & WALLS
Big Six corrugated fibro cement
40mm Celotex LG2 insulation.



SECTION.

revision	date	init.	revision details.

COOPER ARCHITECTURAL DESIGN
BROMAVON, HOCKLESGATE,
FLEET, SPALDING, LINC'S PE12 8LF
Tel/Fax : 01406 423782


Client.
WAYMANS TRANSPORT.

Project.
PROPOSED EXTENSION TO WORKSHOP
CHALK LANE,
SUTTON BRIDGE,
SPALDING,
LINC'S.


Drawing.

SOUTH ... AND DC
HOUSING ... NING
02 JUL 1996
Ref: ... 96.


Scale 1:100	Drawing No.
Date. JUNE '96.	Drawn. J.C.




END ELEVATION



END ELEVATION




SIDE ELEVATION



LONGITUDINAL JOINT.

12mm ø tie bar set parallel and debonded at least half length 900mm long at 600mm c/c



PLAN.

PIT DETAIL 1:25

STEELWORK.
Form all steelwork to Structural Engineers recomendations. All Roof, Side and Gable purlins/rails to be 'Wards Multibeam' or similar fixed in accordance with manufacturers instructions out side steelwork.

EMERGENCY EXIT DOORS.
All doors to be min 838mm wide and fitted with panic latch. Provide 'Push Bar to Open' sign on door. Emergency Exit sign over to B.S. 5499 pt1 Externally provide 1.0m x 1.0m concrete landing level with internal f.f.l.

FLOORS.
Floor slab to comprise of 200mm min. clean and well consolidated hardcore not exceeding 75mm max size, with 50mm blinding. 175mm reinforced concrete RC35 mix. with 1 layers A252 reinforcing fabric min. cover 40mm from top. Longitudinal joints of 900mm long 12mm dia. tie bars at 600mm c/c. at steelwork bay centres. Contraction joints of 1400mm long 12mm dia. bars at 300mm c/c. dowl bars debonded over half length. All at max 30.0m centres. Power Float Finish.
Design Loading. 5KN/m² for industrial occupancy.

LIMITATIONS.
This drawing is limited in the amount of information contained and does not purport to contain a full specification of the works. It is solely for the purpose of obtaining Building Regulation approval.
The drawing must not be used as a contract document alone.
All dimensions shall be taken from site from actual work. Under no circumstances shall measurements be scaled from this drawing for construction or ordering purposes.
All given dimensions shall be checked by the Builder/Contractor and will be his responsibility from commencement of site works.
The works will not be supervised or inspected on site by C.A.D. or any representative thereof. It is the client or their appointed agents responsibility to control workmanship, substitution of materials, adherence to specification, variations to contract etc.

STANDARDS.
All materials to be new unless otherwise stated and all components and materials etc. to be used fitted and installed etc. in strict accordance with manufacturers instruction and relevant Code of Practice.
Materials shall conform to appropriate British Standard Specification or BBA Certificate or European Code equivalent.


HEALTH & SAFETY.
The Employer/Client shall ensure that the selected contractor is conversant with and adopts all measures necessary to achieve compliance with Health & Safety legislation for Building Sites and Work Places.
The Employer /Client is advised that should the works need to comply with the Construction Design and Management Regulations an independant Planning Supervisor will be required.

SCOPE OF THE WORKS.
The works shall comprise of all that is shown on the drawing and details. Work that may not be specifically shown but may be reasonably inferred as necessary to carry out the works shall be deemed to be included.


SURFACE WATER DRAINAGE.
150 dia. half round rainwater gutters to 110 dia. rainwater pipes 110 dia. underground pipes flexibly joined to a fall of 1:70 pipes bedded and surrounded in pea gravel and discharge to 1.2m dia. soakaway min. 5.0m from dwelling.

PITCHED ROOF (Industrial)
Form pitched roof covering of 'Ward Building Components' or similar approved profile 0.7mm thick Plastisol coated steel. 40mm Celotex LG2 or similar insulation (Surface spread of flame Class 1) over purlin in suitable tee bar grid. Provide Mastic tape to all upper surfaces of joints. Roofing system to be fixed to 'Wards Multibeam' or similar galvanised steel purlins space to Structural Engineers recomendations. All purlins to be fixed in accordance with manufacturers instructions


CLADDING (Industrial)
Form all vertical cladding of 'Ward Building Components' or similar approved profile and manufacture. 0.5mm Plastisol coated steel. Lined over rails with 'Celotex LG2' (Surface spread of flame Class 1) or similar insulation in suitable tee bar All outer surfaces of joints to be mastic taped. All on 'Wards Multibeam' or similar galvanised steel rails spaced to Structural Engineers recomendations. All fixed in accordance with manufacturers instructions.



LOCATION PLAN 1:2500



BLOCK PLAN 1:500



SECTION.

RECEIVED
0 5 MAR 1997
Ref: 0607/96

AMENDED
Ref. A1

revision	date	init.	revision details.

COOPER ARCHITECTURAL DESIGN
BRONAVON, HOCKLESBEATE
FLEET, SPALDING, LINC'S PE12 6LF
Tel/Fax : 01406 423782

Client.
WAYMANS TRANSPORT.

Project.
PROPOSED EXTENSION TO WORKSHOP
CHALK LANE,
SUTTON BRIDGE,
SPALDING,
LINC'S.

Drawing.

Scale	Drawing No.
1;100	95069:1
Date. JUNE '96.	Drawn. J.C.