H19/0785/96

21 AUG 1996

Form B (Type III)

Notes: This Form is for use in connection with an application for the Secretary of State for Energy's consent under **section 37** of the Electricity Act 1989 to install and keep installed above ground an electric line of a naminal voltage of less than 132 kilovolts. The Form should be sent **in triplicate** to each District/Borough Council in whose area the proposed development would be situated.

DETAILS OF APPLICANT
Name: East Midlands Electricity plc
Address: Tritton Road
Lincoln
Postcode: LN6 7RS
Telephone Number:

PART 1

East Midlands Electricity plc Application Number EM270/23/98038A Date 16 August 1996
To the Chief Executive Planning Department Council SOUTH HOLLAND DISTRICT
Dear Sir

Electricity Act 1989

Application is being made to the Secretary of State for Energy for his consent to the development described overleaf. The Secretary of State will at the same time be requested to direct that planning permission for this development shall be deemed to be granted. The consent and the direction may be given subject to conditions.

To assist the Secretary of State to determine the application the District/Borough Council is requested to return to me two copies of this Form with Part I Certificate and Part II completed and signed.

Department of the Environment Circular 14/90 (Welsh Office Circular 20/90)[Department of Energy Circular 1/90] describes this procedure and the reason for it.

Yours faithfully
For and on behalf of East Midlands Electricity plc.

Designation:

CERTIFICATE

(To be completed by or on behalf of the District/Borough Council)

The District/Borough Council

(i) object on the grounds set out below/have no objection to make to the development described overleaf.*

(ii) request/do not request that a public inquiry be held pursuant to paragraph 2 of Schedule 8 to the Electricity Act 1989 before the Secretary of State reaches his decision on the application.*

Date Signed

* Delete as appropriate Designation

On behalf of the District/Borough Council

(Reasons for objections)

East Midlands Electricity plc Application Number

(Application dated 16 AUGUST 1996)

PART II - INFORMATION AND OBSERVATION
(To be completed by the District/Borough Council)

Planning Reference Number EM270/23/98038A

1. Names of interested parties consulted about the proposals with details of any observations received.

2. Particulars of any representations which have been made to the local planning authority objecting to the proposals.

3. Have any general or specific restrictions been imposed by any authority on development of the land affected by the proposed development?

PARTICULARS OF PROPOSED DEVELOPMENT AND REPRESENTATIONS
(To be completed by East Midlands Electricity plc)

Application is being made:

(a) for consent under section 37 of the Electricity Act 1989 to install or keep installed an electric line above ground;

(b) ~~for a direction under section 90(2) of the Town and Country Planning Act 1990 that planning permission for the proposed development be deemed to be granted~~.

1. Particulars of proposed development. (These particulars should be accompanied by such plans as may be necessary to enable the local planning authority to identify the land affected by the proposals and to appreciate the nature and extent of the proposed development and by a copy of the environment statement if the applicant has prepared one.)

TO ERECT THE PROPOSED 11000 VOLT OVERHEAD LINE ON WOODEN POLES IN THE PARISH OF SUTTON ST EDMUNDS WITH A TOLERANCE OF 30M EITHER SIDE OF THE ROUTE SHOWN ON THE ATTACHED PLAN

2. Particulars of any representations of objections which have been made to East Midlands Electricity plc.

3. Particulars of the applicant's compliance with his duty under paragraph 1 of Schedule 9 to the Electricity Act 1989.

ENVIRONMENTAL STATEMENT

THE PROPOSED 11KV LINES ARE DIRECT REPLACEMENTS OF EXISTING RADIAL CIRCUITS WHICH ARE IN POOR CONDITION AND NEARING THE END OF THEIR NORMAL LIFE. NEW ROUTES HAVE BEEN SELECTED TO ENSURE POLES AND STAYWIRES ARE LOCATED ON DYKESIDES & CAUSE MINIMUM DISTURBANCE TO THE FARMING ACTIVITY. SHORT LENGTHS OF LV CABLE ARE BEING LAID TO REPLACE THE EQUIVALENT LENGTHS OF LV LINE & A FURTHER SECTION OF REDUNDANT LINE IS TO BE REMOVED.
IN ADDITION 200 M OF 11KV CABLE IS BEING LAID THROUGH KING EDWARDS FARM TO IMPROVE THE VISUAL ASPECT & AVOID FURTHER TREE TRIMMING IN HEAVILY WOODED AREA.
IN CONJUNCTION WITH OTHER SCHEMES PROPOSED IN THE AREA, THE OVERALL CIRCUIT LENGTH WILL BE REDUCED.

Date 16 AUGUST 1996 For and on behalf of East Midlands Electricity plc

Signed Designation:

Note: This part to be completed, dated and signed before submitting to the local planning authority

4. Does the proposed development involve the demolition, alteration or extension of a building of special architectural or historic interest included in a list compiled or approved under section 1 of the Planning (Listed Buildings and Conservation Areas) Act 1990?

5. Does the local planning authority agree that the proposed development should be approved by the Secretary of State for Energy as described? (If the answer is 'NO', please answer question 6.)

6. Would the local planning authority be prepared to agree that the proposed development should be approved subject to modifications or conditions? (If so, specify the modifications or conditions proposed and state whether they are acceptable to the applicant). (Note: the precise form of any modifications or conditions subject to which the consent or direction given is a matter for the Secretary of State, but he will have regard to the form of words used by the local planning authority.)

Date Signed

Designation

On behalf of the Council

(Local planning authority for the area in which the proposed development is to be carried out.)

Two completed copies of this Form, both signed, should be returned to East Midlands Electricity plc for submission by them to the Department of Energy.

Department of Trade and Industry
Electricity Directorate
1 Victoria Street
London SW1H 0ET

Enquiries 0171 - 215 5000
Direct Line 0171 - 215 2768/2866
Fax 0171 - 630 9570

The Secretary
East Midlands Electricity plc
Lincoln

Dear Sir

Our Reference AAM/6/123

Date: 29 OCT 1996

OVERHEAD LINES
ELECTRICITY ACT 1989
TOWN AND COUNTRY PLANNING ACT 1990.

With reference to the application particulars of which are specified below, I am directed by the Secretary of State to inform you that consent is hereby granted pursuant to section 37(1) of the Electricity Act 1989 ("the 1989 Act") to the installing above ground of electric lines ("the lines") particulars of which are specified below.

Pursuant to section 37(3) of the 1989 Act this consent is given subject to the following conditions:

1. Subject to regulations 50,51,71 and 72 of The Conservation (Natural Habitats, &c.) Regulations 1994, the Secretary of State may review this consent at any time after a period of five years from the date hereof, and upon such review, after giving all persons concerned an opportunity of being heard, he may vary or revoke his consent.

2. If the Secretary of State revokes this consent the lines shall be removed within such period as the Secretary of State may direct.

Pursuant to section 90(2) of the Town and Country Planning Act 1990 ("the 1990 Act") the Secretary of State hereby directs that planning permission for the development shall be deemed to be granted subject to the following condition(s):

1. The development to which this permission relates shall be begun not later than the expiration of five years beginning with the date hereof.

Reason: For conformity with section 91 of the 1990 Act.

2. The Company shall dismantle and remove from the site any redundant lines and apparatus within six months from the date of commissioning of the lines.

Reason: To restore the land as far as practicable to its condition before the redundant lines and apparatus were installed.

PLANNING AUTHORITY REFERENCE: H19/0785/96

APPLICANT COMPANY: East Midlands Electricity plc

DATE AND REFERENCE OF APPLICATION: 27 September 1996 EM 23/270-98038A

PARTICULARS OF OVERHEAD LINES:

Situated in the Parish of Sutton St Edmunds

Route as indicated on Map No 96/98038 or within a distance not exceeding 30 metres on either side thereof.

Voltage 11,000

Yours faithfully



Authorised by the Secretary of State