

Online Comment

Application H19-1068-15
Location Coronation Avenue Throckenholt Spalding PE12 0QT
Proposal Details of external materials, landscaping, boundary treatment and contamination report (Conditions 4,5,6 and 7 of H19-0083-15)

Name J Reith
Address Environmental Health Technician Safety and Environment

Date Submitted 16-12-15
For/Against Comments

The Phase I & II Geo-Environmental Assessment by EPS dated 23 October 2015 satisfies parts 1 and 2 of the contaminated land condition. However the condition can not be discharged at this stage as the report has found that remediation works are required. I will require a verification report to evidence these works in due course.