Council Offices
Priory Road
Spalding
Lincolnshire
PE11 2XE
Admin 01775 764723
DC Officers 01775 764703
facsimile 01775 762937
planningadvice@sholland.gov.uk
www.sholland.gov.uk

Status Design
2 Edinburgh Walk
Holbeach
Spalding
Lincs
PE12 7AP

TOWN AND COUNTRY PLANNING ACT 1990

FULL

Reference: H20-0043-18 **Date of Decision:** 25th February 2019

Applicant: Kirk Home Developments Ltd - Mr J Kirk
C / O South Lincs Plant Hire
Enterprise Way
Spalding
Lincs
PE11 3YR

Location: Adjacent: Havencombe Chapelgate Sutton St James Spalding

Description: Residential development for 27 dwellings including roads, etc

South Holland District Council hereby give notice that this application has been GRANTED (or equivalent) subject to the following condition(s):

1 The development must be begun not later than the expiration of three years beginning with the date of this permission.

Reason: As required by Section 91 of the Town and Country Planning Act 1990 as amended by the Planning and Compulsory Purchase Act 2004.

2 The development hereby permitted shall be carried out in accordance with the following approved plans and documents:
Application form
Design and Access Statement SC16-049/DAS
Topographical Survey 37815/02
Site location
Site Location Plan 06-0041-002 P1
SD16-049 The Gascon E
SD16-049 The Persia E
SD16-049 The Tamworth D

SD16-049 The Duroc D
Flood Risk Assessment. Geoff Beel Consultancy. January 2018. GCB/STATUS DESIGN
Drainage Strategy Report 06-0041 DSR/001 03/05/2018 Rev A
Phase 1 and 2 Intrusive Ground Investigation Report R17053 April 2018
Flood Routing Plan 06-0041-011/P1
Wastewater Plan 240599-1
Drainage Area Plan 06-0041-010 P2
Longitudinal Sections - Sheet 1 of 2 06-0041-014 P1
Longitudinal Sections - Sheet 2 of 2 06-0041-015 P1
Hydro International Sales Quote HQT-011175
Polypipe Ridgidrain Data Sheet. Issue 5 - JAN 2016
External Works - Sheet 1 of 2 06-0041-005 P2
External Works - Sheet 2 of 2 06-0041-006 P2
Section 38 Layout 06-0041-003 P2
Section 38 Construction Details - Sheet 2 of 2. 06-0041-018 P1
Section 104 Layout 06-0041-004 P2
External Levels - Sheet 1 of 2 06-0041-007 P2
External Levels - Sheet 2 of 2 06-0041-008 P2
Section 38 Construction Details - Sheet 1 of 2 06-0041-017 P1
Ridgidrain Advanced Drainage System No 00/3678
Ridgidrain Advanced Drainage System No 02/H068 Product Sheet 1
Ridgidrain Advanced Drainage System No 02/H068 Product Sheet 3
Ridgidrain Advanced Drainage System No 00/3678 Product Sheet 3
1 in 1, 2, 3, 5 and 30 Year Surface Water Drainage Calculations
1 in 100 Year + 40% Climate Change Surface Water Drainage Calculations
WREKIN The New Highway Ironwork Range
300mm Square Flap Valve - ATK300
Stanton Bonna Innovative Precast Concrete Solutions
Signing and Lining 06-0041-009 P2
Althon HDPE Flap Valve
Althon Installation Instructions

Reason: For the avoidance of doubt and in the interests of proper planning.

3 Before the commencement of the development hereby permitted beyond oversite a schedule of external materials of construction of buildings and hard surfaced areas shall be submitted to and approved in writing by the Local Planning Authority. The development shall be constructed in accordance with the materials so approved.

Reason: To ensure that the Local Planning Authority retains control over the external materials of construction of the development in the interests of the character and appearance of the development and the visual amenity of the area in which it is set.
This Condition is imposed in accordance with Policy SG14 of the South Holland Local Plan, 2006.

4 Before the commencement of the development hereby permitted beyond oversite, a scheme to deal with any contamination of land or pollution of controlled waters has been submitted to and approved in writing by the Local Planning Authority (LPA) and until the measures approved in that scheme have been implemented. The scheme shall include all of the following measures:

i) a desk-top study carried out to identify and evaluate all potential sources of contamination and the impacts on land and/or controlled waters, relevant to the site. The desk-top study shall establish a 'conceptual site model' and identify all plausible pollutant linkages. Furthermore, the assessment shall set objectives for intrusive site investigation works/Quantitative Risk Assessment (or state if none required). Two full copies of the desk- top study and a non-technical summary shall be submitted to the LPA without delay upon completion.
ii) if identified as being required following the completion of the desk-top study, a site investigation shall be carried out to fully and effectively characterise the nature and extent of any land contamination and/or pollution of controlled waters. It shall specifically include a risk assessment that adopts the Source-Pathway-Receptor principle, in order that any potential risks are adequately assessed taking into account the sites existing status and proposed new use. Two full copies of the site investigation and findings shall be forwarded to the LPA without delay upon completion.
iii) thereafter, a written method statement detailing the remediation requirements for land contamination and/or pollution of controlled waters affecting the site shall be submitted to and approved in writing by the LPA, and all requirements shall be implemented and completed to the satisfaction of the LPA. No deviation shall be made from this scheme. If during redevelopment contamination not previously considered is identified, then the LPA shall be notified immediately and no further work shall be carried out until a method statement detailing a scheme for dealing with the suspect contamination has been submitted to and agreed in writing by the LPA.
iv) two full copies of a full closure report shall be submitted to and approved in writing by the LPA. The report shall provide verification that the required works regarding contamination have been carried out in accordance with the approved Method Statement(s). Post-remediation sampling and monitoring results shall be included in the closure report to demonstrate that the required remediation has been fully met.

Note
The applicant is advised that the phased risk assessment required by the Contaminated Land Scheme Condition should be carried out in accordance with the procedural guidance of the Environmental Protection Act 1990 Part 11A.
The applicant's attention is also drawn to the document entitled "Developing Land Within Lincolnshire - A guide to submitting planning applications to develop land that may be contaminated", which can be obtained through the Local Environmental Health Department.

Reason: To assess whether the site is polluted and to address any pollution to ensure a satisfactory development. This issue is integral to the development and therefore full details need to be finalised prior to the commencement of works.
This Condition is imposed in accordance with Policy SG13 of the South Holland Local Plan, 2006.

5 Before the commencement of the development hereby permitted beyond oversite, the approval of the Local Planning Authority is required to a scheme of landscaping and tree planting for the site indicating, inter alia, the number, species, heights on planting and positions of all the trees, together with details of post-planting maintenance. Such scheme as is approved by the Local Planning Authority shall be carried out in its entirety within a period of twelve months beginning with the date on which development is

commenced. All trees, shrubs and bushes shall be maintained by the owner or owners of the land on which they are situated for the period of five years beginning with the date of completion of the scheme and during that period all losses shall be made good as and when necessary.

Note: The applicant is recommended to employ a qualified and experienced landscape designer to produce a landscaping scheme for the development.

Reason: To ensure that the development is adequately landscaped, in the interests of its visual amenity and that of the area in which it is set.
This Condition is imposed in accordance with Policy SG18 of the South Holland Local Plan, 2006.

6 Prior to its installation, details of the proposed boundary treatment, including a schedule of materials, and details of the size and species of any hedging, shall be submitted to and approved in writing by the Local Planning Authority, and the details so approved shall be implemented in full before the development is first brought into use.

Reason: In the interests of the character and appearance of the development and the visual amenity of the area in which it is set.
This Condition is imposed in accordance with Policy SG14 of the South Holland Local Plan, 2006.

7 Before any dwelling is occupied, all of that part of the estate road and associated footways that forms the junction with the main road and which will be constructed within the limits of the existing highway, shall be laid out and constructed to finished surface levels in accordance with details to be submitted to, and approved in writing by, the Local Planning Authority.

In the interests of safety, to avoid the creation of pedestrian trip hazards within the public highway from surfacing materials, manholes and gullies that may otherwise remain for an extended period at dissimilar, interim construction levels.
This Condition is imposed in accordance with Policy SG15 of the South Holland Local Plan, 2006.

8 The permitted development shall be undertaken in accordance with an Estate Road Phasing and Completion Plan, which shall be approved in writing by the Local Planning Authority. The Plan shall set out how the construction of the development will be phased and standards to which the estate roads on each phase will be completed during the construction period of the development.

Reason: To ensure that a safe and suitable standard of vehicular and pedestrian access is provided
for residents throughout the construction period of the development.
This Condition is imposed in accordance with Policy SG15 of the South Holland Local Plan, 2006.

9 A detailed scheme of construction management to minimise disturbance during the construction process through noise, dust, vibration and smoke shall be submitted to and approved in writing by the Local Planning Authority before the development commences

beyond oversite and the construction process shall be carried out in accordance with the scheme so approved.

Reason: In the interests of the amenity of local residents. This issue is integral to the development and therefore full details need to be finalised prior to the commencement of works.
This Condition is imposed in accordance with Policy SG17 of the South Holland Local Plan, 2006.

10 The development hereby permitted shall be carried out in accordance with the approved Flood Risk Assessment (FRA) and in particularly the following mitigation measures detailed within:
-Finished floor levels of all two storey dwellings shall be set no lower than 300mm above existing ground levels;
-Finished floor levels of all single storey dwellings shall be set no lower than 500mm above existing ground levels;
-Flood resilient and resistant construction measures shall be incorporated throughout the development.

The mitigation measures shall be fully implemented prior to occupation and subsequently in accordance with the timing/phasing arrangements embodies within the scheme, or within any other period as may subsequently be agreed, in writing, by the local planning authority.

Reason: To ensure that the development does not increase the risk of flooding or be at risk of flooding.
This Condition is imposed in accordance with national guidance contained in the National Planning Policy Framework, 2019.

11 The permitted development shall be undertaken in accordance with a surface water drainage scheme which shall be approved in writing by the Local Planning Authority.
The scheme shall:
· be based on sustainable drainage principles and an assessment of the hydrological and hydrogeological context of the development;
· provide details of how run-off will be safely conveyed and attenuated during storms up to and including the 1 in 100 year critical storm event, with an allowance for climate change, from all hard surfaced areas within the development into the existing local drainage infrastructure and watercourse system without exceeding the run-off rate for the undeveloped site;
· provide attenuation details and discharge rates which shall be restricted to either 1.4 or 2.4 litres per second; in agreement with the North Level District Internal Drainage Board for discharge to their open water course.
· provide details of the timetable for and any phasing of implementation for the drainage scheme; and · provide details of how the scheme shall be maintained and managed over the lifetime of the development, including any arrangements for adoption by any public body or Statutory Undertaker and any other arrangements required to secure the operation of the drainage system throughout its lifetime.
No dwelling shall be occupied until the approved scheme has been completed or provided on the site in accordance with the approved phasing. The approved scheme shall be retained and maintained in full, in accordance with the approved details.

Reason: To ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, the permitted development.
This Condition is imposed in accordance with Policies SG12 and SG13 of the South Holland Local Plan 2006.

12 Before the commencement of the development hereby granted beyond oversite, details of the means of foul water disposal shall be submitted to and approved in writing by the Local Planning Authority. The details so approved shall be implemented in full before the development hereby permitted is first brought into use.

Reason: To ensure that the site is adequately drained and to avoid pollution.
This Condition is imposed in accordance with Policies SG12 and SG13 of the South Holland Local Plan 2006.

13 Notwithstanding the provisions of the Town and Country Planning (General Permitted Development) Order 2015, (or any Order or Statutory Instrument revoking and re-enacting that Order), none of the following developments or alterations shall be carried out.

i) the erection of freestanding curtilage buildings or structures including car ports, garages, sheds, greenhouses, pergolas or raised decks;
ii) the erection of house extensions including dormer windows, conservatories, garages, car ports, porches or pergolas;
iii) alterations including the installation of replacement or additional windows or doors and the installation of roof windows.

Reason: To ensure that the Local Planning Authority retains control over the future extension and alteration of the development, in the interests of its architectural and visual integrity, levels of residential amenity and the visual amenity and character of the area within which it is set.
This Condition is imposed in accordance with Policies SG14 and SG17 of the South Holland Local Plan, 2006.

Notes:

This planning permission is subject to an Agreement under Section 106 of the Town & Country Planning Act 1990 dated 22 February 2019 and can only be implemented as a consequence of meeting the provisions of that Agreement

The Local Planning Authority has acted positively and proactively in determining this application by assessing it against all material considerations, including national guidance, planning policies and representations that have been received during the public consultation exercise, and by identifying matters of concern within the application and negotiating, with the Applicant, acceptable amendments to the proposal to address those concerns. As a result, the Local Planning Authority has been able to grant planning permission for an acceptable proposal.

This decision notice, the relevant accompanying report and the determined plans can be

viewed online at http://planning.sholland.gov.uk/OcellaWeb/planningSearch

Please contact the Lincolnshire County Council Streetworks and Permitting Team on 01522 782070 to discuss any proposed statutory utility connections and any other works which will be required within the public highway in association with the development permitted under this Consent. This will enable Lincolnshire County Council to assist in the coordination and timings of these works.

All roads within the development hereby permitted must be constructed to an engineering standard equivalent to that of adoptable highways. Those roads that are to be put forward for adoption as public highways must be constructed in accordance with the Lincolnshire County Council Development Road Specification that is current at the time of construction and the developer will be required to enter into a legal agreement with the Highway Authority under Section 38 of the Highways Act 1980. Those roads that are not to be voluntarily put forward for adoption as public highways, may be subject to action by the Highway Authority under Section 219 (the Advance Payments code) of the Highways Act 1980.

Please contact the Lincolnshire County Council Streetworks and Permitting Team on 01522 782070 to discuss any proposed statutory utility connections and any other works which will be required within the public highway in association with the development permitted under this Consent. This will enable Lincolnshire County Council to assist in the coordination and timings of these works.

The Council is in the process of finalising a new Local Plan (the South East Lincolnshire Local Plan). The new Local Plan has been through its formal Examination process and the final report from the Planning Inspectorate has now been received. However, the new Local Plan has yet to be formally adopted. The saved policies in the 2006 Adopted South Holland Local Plan therefore remain material. However, the new Local Plan is now considered to carry significant weight in the decision-making process.



Phil Norman
Planning and Building Control Manager
South Holland District Council

BUILDING REGULATIONS:
This decision refers only to planning permission as granted under the Town and Country Planning Act 1990. The works that you are proposing may also require Building Regulations and this planning permission does not give authority under Building Regulations to commence work. Please contact the Building Control section for further information on 01775 764557 or bcadmin@sholland.gov.uk

RIGHTS OF APPEAL

Appeals to the Secretary of State

If you are aggrieved by the decision of your Local Planning Authority to refuse permission for the proposed development or grant consent subject to conditions, then you can appeal to the Secretary of State under Section 78 of the Town and Country Planning Act 1990 or Section 20 of the Planning (Listed Building and Conservation Areas) Act 1990.

Timescales for appealing

The deadlines for appeals are calculated from the **date of decision** and are as follows for the types of applications below:

12 Weeks	6 Months	8 Weeks
Householder Applications	Planning Permission	Consent to Display Adverts
Minor Commercial Development	Listed Building Consent	
Agricultural Determinations	Other Prior Approval Applications	
Householder Prior Approval Applications		

Enforcement Notices

If an enforcement notice was served prior to the planning application being determined then the deadline for appealing is 28 days from the date of the **planning refusal**

If an enforcement notice is served after the planning application is determined then the deadline for appealing is 28 days from the date of the **enforcement notice** OR **the timescales stated above for each application type** from the date of the planning refusal - whichever is sooner.

All appeals must be made using an Appeal Form which you can get from The Planning Inspectorate at Temple Quay House, 2 The Square, Bristol, BS1 6PN (tel: 0303 444 5000) or you can submit your appeal online at:

http://www.planningportal.gov.uk/planning/appeals/online/makeanappeal

The Secretary of State can allow a longer period for giving notice of an appeal but he will not normally be prepared to use this power unless there are special circumstances which excuse the delay in giving notice of appeal.

The Secretary of State need not consider an appeal if it seems to him that the Local Planning Authority could not have granted planning permission for the proposed development or could not have granted it without the conditions it imposed, having regard to the statutory requirements, to the

provisions of the development order and to any directions given under the order. In practice the Secretary of State does not refuse to consider appeals solely because the Local Planning Authroity based its decision on a direction given by him.

For detailed information on appeals, appeal types and guidance on the appeals process please visit:

http://www.planningportal.gov.uk/planning/appeals/planningappeals

Purchase Notices

If either the Local Planning Authority or the Secretary of State refuses permission to develop land or grant it subject to conditions the owner may claim that he can neither put the land to a reasonably beneficial use in its existing state nor can he render the land capable of a reasonably beneficial use by the carrying out of any development which has been or would be permitted.

In these circumstances the owner may serve a purchase notice on the Council in whose area the land is situated. This notice will require the Council to purchase his interest in the land in accordance with the provisions of the Part VI of the Town and Country Planning Act 1990 or Section 32 of the Planning (Listed Building and Conservation Areas) Act 1990.

Compensation

In certain circumstances compensation may be claimed from the Local Planning Authority if permission is refused or granted subject to conditions by the Secretary of State on appeal or on reference of the application to him.

These circumstances are set out in Section 114 and related provisions of the Town and Country Planning Act 1990 and Section 27 of the Planning (Listed Building and Conservation Areas) Act 1990.