Online Comment

Application	H20-0322-18
Location	Poplar Farm Old Fendyke Sutton St James PE12 0HE
Proposal	Proposed glasshouse, including 2 lagoons

Name	Steve Branson
Address	SHDC Priory Road

Date Submitted	11-05-18
For/Against	Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.