

Online Comment

Application H20-0494-17
Location BENAMY CHILDERSGATE SUTTON ST JAMES PE12 0HX
Proposal Proposed farm barn

Name Noise and Contaminated Land
Address Environmental Health Technician Safety and Environment

Date Submitted 30-06-17
For/Against Comments

No objection, however I would wish to attach the following condition;

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A) when measured as a minute L(A)eq at any residential boundary not within the applicant's ownership.