

Online Comment

Application	H20-0763-16
Location	Land behind Necahen Lodge 120 Bell's Drove Sutton St James PE12 0JG
Proposal	Proposed telecommunication equipment

Name	Steve Branson
Address	Environmental Health Technician Safety and Environment

Date Submitted	15-09-16
For/Against	Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A) when measured as a 15 minute LAeq at any residential boundary not within the applicant's ownership.