PROPOSED ANNEX TO THE REAR OF VENACRES, PARSONAGE LANE, SUTTON ST JAMES, SPALDING, PE12 0JA

FLOOD RISK ASSESSMENT



View looking north east from gravel menage

S M Hemmings B Sc C Eng MICE MIWEM,
13 Lea Gardens,
Peterborough,
PE3 6BY

This flood risk assessment has been prepared solely to support the planning application for a development at Parsonage Lane, Sutton St James. The author has made every effort to provide an accurate assessment of the flood risk but accepts no liability should the information be found to be incorrect or incomplete, or if it is used for any other purposes other than for which it was originally commissioned.

Introduction


A planning application is due to be submitted to South Holland District Council for permission to construct an annex on the site of a former barn east of the existing bungalow called Venacres, Parsonage Lane, Sutton St James. The area is at present a small area of disused land immediately north of the existing stable block.

The site is within Flood Zone 3 as shown on the Environment Agency's Flood Zone Map. These maps do not take into account existing flood defences.

The Planning Application requires a Flood Risk Assessment to be carried out as specified in the Practice Guidance to the National Planning Policy Framework Development and Flood Risk. The site is shown within the defended area of the South Holland District Council's Strategic Flood Risk Assessment (SHDC SFRA) map and is located in the North Level Internal Drainage Board district.

Environment Agency (EA) Flood Zones

The map below is taken from the Environment Agency website and shows the flood zones in the area.



© Environment Agency copyright and / or database rights 2021. All rights reserved. © Crown Copyright and database right 2021. Ordnance Survey licence number 100024198.

It can be seen that the whole of this immediate area east of Sutton St James is in Flood Zone 3.

Application Site

The development is located on the western side of the River Nene. The National Grid Reference of the site is 543030 318520.

The location of the site is shown on the plan at the end of this document.

As the site is within a defended area the proposed development can be categorised as within Flood Zone 3(a) as detailed on the Environment Agency's flood zone maps without defences, as defined in Table 1 of the Technical Guidance.

Applying the flood risk vulnerability classification in Table 2 of the Guidance, a development consisting of a dwelling house is classified as "more vulnerable".

Table 3 of the Guidance is shown below:

Flood Zones	Flood Risk Vulnerability Classification				
	Essential infrastructure	Highly vulnerable	More vulnerable	Less vulnerable	Water compatible
Zone 1	✓	✓	✓	✓	✓
Zone 2	✓	Exception Test required	✓	✓	✓
Zone 3a †	Exception Test required †	✗	Exception Test required	✓	✓
Zone 3b *	Exception Test required *	✗	✗	✗	✓*

Therefore it can be seen that for "More vulnerable" development the sequential and the exception tests need to be applied to the development.

Sequential Test

The aim of the Sequential Test, as set out in the Planning Practice Guidance, is to ensure that a sequential approach is followed to steer new development to areas with the lowest probability of flooding. The flood zones as defined in the Strategic Flood Risk Assessment for the area provide the basis for applying the Test. The aim is to steer new development to Flood Zone 1 (areas with a low probability of river or sea flooding). Where there are no reasonably available sites in Flood Zone 1, local planning authorities in their decision making should take into account the flood risk vulnerability of land uses and consider reasonably available sites in Flood Zone 2 (areas with a medium probability of river or sea flooding), applying the Exception Test if required. Only where there are no reasonably available sites in Flood Zones 1 or 2 should the suitability of sites in Flood Zone 3 (areas with a high probability of river or sea flooding) be considered, taking into account the flood risk vulnerability of land uses and applying the Exception Test if required.

It is assumed that the annex will provide accommodation similar to an extension to the existing bungalow. As such it is not possible to locate this annex on an alternative site.

The safety of the site will be delivered by ensuring the ground floor level is above the predicted flood level in 2115.

Therefore it is considered that the sequential test is passed.

Exception Test

The Sequential Test has demonstrated that it is not possible, consistent with wider sustainability objectives, for the development to be located in zones with a lower probability of flooding. Therefore the Exception Test must be applied and for this to be passed:

- It must be demonstrated that the development provides wider sustainability benefits to the community that outweigh flood risks, informed by the Strategic Flood Risk Assessment; and
- A site-specific flood risk assessment must demonstrate that the development will be safe for its lifetime taking into account of the vulnerability of its users, without increasing flood risk elsewhere, and where possible will reduce flood risk overall.

Both parts of this test must be satisfied in order for the development to be considered appropriate in terms of flood risk. There must be robust evidence in support of every part of the test.

The first section will be demonstrated by the Supporting Planning Statement and compliance with South Holland District Council's planning policies.

This flood risk assessment will demonstrate that the development will be safe for its lifetime and it will not increase flood risk elsewhere.

Strategic Flood Risk Assessment

The Strategic Flood Risk Assessment (SFRA) written for the South Holland District Council (SHDC) in 2010 provides details of the actual flood risk in the Council's area. This information has not been updated and reference to the maps in this document give the following information for the actual flood risk and hazard at the site for the 1% fluvial event and 0.5% tidal event.

For the present day	Depth of flooding … zero
	Extent of flooding .. Low or medium
	Velocity ……. zero
For year 2115	Depth of flooding … zero
	Extent of flooding .. Low or medium
	Peak Velocity …… zero

The maps showing the residual flood hazard were revised in the 2016 update of the South Holland District Council Strategic Flood Risk Assessment which can be found on the website of the South East Lincolnshire Joint Planning Committee. The hazards are as follows for the 1% fluvial or 0.5% tidal event probability:

For the present day	Depth of flooding…. zero
	Extent of flooding …low or medium
	Hazard ……. zero

	Velocity ……..	zero
For the year 2115	Depth of flooding ….	0mm – 250mm
	Extent of flooding …	High
	Hazard ……	Less than 0.75 (low hazard)
	Velocity …….	0 – 0.3 m/sec

Figure 16 of the general maps shows that the site is not within the rapid inundation zone for the present day or in 2115.

Maximum flood level and bank levels in the River Nene

The maximum levels in this tidal section of the River Nene 5.8km east of the site are as follows:

	2007	2115
Peak 1 in 200 year level	5.79m OD	6.93m OD
Peak 1 in 1000 year level	6.13m OD	7.27m OD

The defence level (top of left bank) at chainage between the South Holland Main Drain and the North level Main Drain is between 7.00m and 7.30mOD.

Information from Environment Agency

The Environment Agency has produced mapping which shows the maximum hazard, depth and velocity predicted following breaching of the tidal defences of the tidal River Nene east of the site. The EA have stated that the site would not be affected by overtopping of the defences.

The maps of breaching show the following predictions for hazard, maximum depth and maximum velocity at the development site:

	Maximum Hazard	Maximum Depth	Maximum Velocity
1 in 200 year in 2006	zero	zero	zero
1 in 1000 year in 2006	zero	zero	zero
1 in 200 year in 2115	0 – 0.75	0 – 250mm	0 – 0.3m/sec
1 in 1000 year in 2115	0.75 – 1.25	250mm – 500mm	0 – 0.3m/sec

The maps supplied by the Environment Agency are reproduced on pages 13 and 16 of this report.

Existing Flood Alleviation Measures

The site is within a defended flood plain, as defined in Appendix 1 of the Environment Agency's "Policy and Practice for the Protection of Flood Plains", which is considered to be passive until such time that a flood greater than the defences can withstand occurs. The likelihood of flooding occurring due to overtopping or failures of the defences is considered to be very low.

The site is located approximately 4.0 km from the tidal section of the River Nene, which is maintained by the Environment Agency.

The site is located approximately 15.0 km from the Wash banks which are maintained by the Environment Agency.

The site is located approximately 1.1km south of the South Holland Main Drain, which is maintained by South Holland IDB.

The site is located approximately 1.9km north west of the North Level Main Drain which is maintained by North Level IDB.

The main watercourses in this area north of Sutton St James are maintained by South Holland IDB.

Existing Ground Levels

A small survey has been carried out which has been referenced to the existing Ordnance Survey bench mark on the house on the corner of Parsonage Lane and Draw Dyke. The level of the existing gravel menage is 2.26m OD and the concreted area in front of the stables is 2.31m OD.

The level of Parsonage Lane west of the existing bungalow is 2.32m OD and the ground floor level of the existing bungalow is 2.39m OD. The blockwork parking area in front of the bungalow is 150mm below the level of the bungalow.

Potential Sources of Flooding

The potential sources of flooding to the site are:-

1. Failure or overtopping of tidal defences of the River Nene.
2. Overtopping of the South Holland Main Drain
3. High water levels in IDB drainage channels.
4. Localised flooding due to failure of highway drainage

1. Failure or overtopping of tidal defences of the River Nene

The west bank of the River Nene is approximately 4.0 km east of the site of the proposed development, and the Wash Banks are 15km north of the site at their nearest point. The hazard from a breach in the River Nene east of the development site will be considered to be the major risk to the site.

The maps supplied by the EA (and also in the South East Lincolnshire SFRA) show predicted flood depths on the site of the proposed annex of between 0 and 250mm in a 1 in 200 year event in 2115.

Adequate mitigation against the risk of flooding from this source will be provided by raising the ground floor level of the proposed annex above the predicted flood level.

2. **Overtopping of the South Holland Main Drain**

There is a risk of flooding to the site if water levels in the South Holland Main Drain were to become very high and flood onto the surrounding land. This watercourse is 1.9km north of the proposed site.

The risk of this can be considered to be low as the normal water level of the Main Drain is approximately 0.0m OD and predicted levels in a 1 in 100 year event stay within bank.

Therefore with the added precaution that ground floor level of the proposed property will be raised at 300mm above ground level this source of flooding can be considered to be adequately mitigated.

3. **High Water Levels in IDB drains**

Although the whole of this area is below high tide level in the Wash and the River Nene, the retained water levels in the drainage channels ensure that the risk of flooding is extremely low. North Level IDB maintains a system of sluices, pumping stations, and drainage channels which convey surface water into the River Nene and the Wash and control water levels throughout the North Level IDB area.

There are possibilities of failure of outfall sluices, but these are mitigated by the high level of maintenance given to these structures by the IDB. If a failure did occur the IDB would immediately be warned of the problem by their telemetry system and take action to repair the fault or to bring in temporary pumps to reduce the risk of any flooding in the area. Similarly any failures of culverts or other blockages would be dealt with immediately.

IDB systems are designed to provide a freeboard of between 600mm and 1000mm to all land in a 1 in 10 year return period rainfall event. This normally provides a standard of service of between 1 in 50 years and 1 in 100 years against flooding. In an extreme event water levels will rise but this will be a slow process and it would be at least 24 hours before levels were high enough to begin to flood low land in the area.

North Level IDB have a policy of monitoring standards of protection in all their catchments and will carry out improvements to pumping stations, sluices and drainage channels to ensure they continue to provide satisfactory standards of protection with higher run-offs predicted with climate change.

The water level in the dykes around Venacres is controlled by the School Drain west of the site which flows southwards into the North Level Main Drain. The water level in the Main Drain and the areas alongside this large watercourse are controlled by Tydd Gott Pumping Station, which is the outfall for a greater part of the North Level IDB district with a total area of 34,000ha. This pumping station pumps the flow into the tidal River Nene south of Sutton Bridge.

It is unlikely that any failure of assets such as pumping stations, sluices or drainage channels would lead to overtopping of the watercourse because South Holland IDB have an excellent maintenance regime and monitor all assets with a modern telemetry system.

Therefore the IDB system provides an adequate control of water levels in the area to mitigate against any flooding in a 1 in 100 year event.

4. **Localised Flooding due to failure of local drainage systems**

Any localised flooding that could occur on the site will be mitigated by raising the floor levels of the proposed annex by a minimum of 300mm.

Extent of known Flooding

During the preparation of this assessment, no evidence was discovered of the site or any of the adjoining properties having been flooded in the past.

Probabilities and Trends of Flooding

The probability of this development flooding from Environment Agency main river is very low. In an extreme event any effect on this location would not be sudden and there would be time for residents to take precautionary measures to limit the impact of any flooding that may occur.

Residual Risk – Extreme Events

The residual risk from extreme events is very low on this site. The major risk to the site is from a breach or overtopping of the tidal defences

The risk of this happening in this case is low and the hazard from any flooding is also low.

Climate Change

The predictions of flood depths for this flood risk assessment use information provided by the Environment Agency which was produced in 2006. The EA have issued new guidance on recommended contingency allowances for predicted sea level rises, fluvial flows and rainfall intensities which from 19th February 2016 needs to be considered in the FRA. The effects of these new recommendations are considered in Appendix A of this report (pages 17 to 20). It is concluded that no extra mitigation measures are necessary to comply with the new guidance on climate change.

South East Lincs Advice Matrix

Advice can be found on the recommended mitigation required by referring to a spreadsheet on the South East Lincolnshire website. The flood hazard is shown below:



As the development is in flood zone 3 and the flood hazard is “low hazard” (0 – 0.75) reference should be made to Category F8 which states:

The NPPF requires that proposals are accompanied by a Flood Risk Assessment which contains evidence that appropriate mitigation measures / flood resilience techniques have been incorporated into the development.


The applicant is advised to refer to the document “Improving Flood Performance of New Buildings Flood Resilient Construction (DCLG2007).

Finished floor levels (FFL) should be set 300mm above ground level for two storey proposals. Single storey proposals must set FFL’s above the 0.1% event breach in the 2115 scenario.

Summary of Risk of Flooding to the Site

The main risk of flooding to the site is if a breach were to occur in the west bank of the tidal River Nene. The risk of this happening along this section of bank can be considered to be low. The bank has a wide top and bank slopes are not steep.

The relevant part of the Environment Agency map showing the predicted peak depths in this area if a breach occurred in the west bank of the River Nene in 2115 in a 1% fluvial and 0.5% tidal event probability is shown below.



It can be seen that the predicted flood depths in the field are zero and 0 – 250mm (yellow).

From the above it is estimated that the predicted flood level in a 1 in 200 year event would be 2.60m ODN.

The risk of flooding from high water levels in the IDB system is extremely low, and adequately mitigated by raising ground floor levels of the proposed house 300mm above existing ground level.

Recommendations

In any area at risk of flooding it is recommended that new dwellings should be of two story construction with all bedrooms at first floor level. This will provide a refuge for residents if the building becomes flooded after a major breach of the tidal bank, and ensure there is no danger to residents when they are asleep.

The ground floor level of the proposed annex should be a raised to a minimum level of 2.6m ODN, which is 210mm higher than the bungalow on the site, and this will also be a minimum of 300mm above the existing ground level on the site.

Occupiers of the property should register with the Environment Agency's Floodline Warnings Direct Service.


Surface water from the roof of the proposed annex should be discharged into a soakaways.

S M HEMMINGS B Sc C Eng MICE MIWEM


stuart.hemmings@btinternet.com

27th June 2022


LOCATION PLAN



PLAN OF IDB DRAINS




PLAN OF PROPOSED DEVELOPMENT




EA MAP SHOWING TIDAL BREACHING HAZARDS IN

1 in 200 YEAR EVENT IN 2006




EA MAP SHOWING TIDAL BREACHING HAZARDS IN

1 in 1000 YEAR EVENT IN 2006




EA MAP SHOWING TIDAL BREACHING HAZARDS IN

1 in 200 YEAR EVENT IN 2115



EA MAP SHOWING TIDAL BREACHING HAZARDS IN

1 in 1000 YEAR EVENT IN 2115



APPENDIX A CLIMATE CHANGE

The Environment Agency has issued revised guidance on climate change and have now stated that the new predictions should be considered and incorporated into all flood risk assessments produced after 19th February 2016.

Listed below are the climate change allowances in three documents:

- South Holland SFRA
- EA guidance (2013)
- Revised EA guidance

The recommendations in each document are shown below.

2010 South Holland DC SFRA

The SHDC SFRA states that the the following allowances have been made for climate change:

4.4 Climate Change

Scenarios for the years 2055 and 2115 include for climate change contingency allowances to the amount suggested by PPS25[1]. These allowances are expressed in *Table 2*. Percentage increases are relative to the present-day.

Table 2 – Adopted Climate change contingency allowances

Parameter	Year 2055	Year 2115
Sea level rise (m)	+ 0.33	+ 1.14
Extreme wave height	+ 10%	+ 10%
Peak river flow and volume	+ 20%	+ 20%
Peak rainfall intensity	+ 20%	+30%

Where flows arise from pumping rather than natural run-off, notably in the Vernatt's Drain and for the Fenland subcatchments of the South Forty Foot Drain, peak flow rates for future eras have been taken as equal to current rates since this SFRA assumes all flood risk management measures will remain in their current state.

2013 Guidance to Planners

Guidance to planners was issued by EA in September 2013

Table 1: Recommended contingency allowances for net sea level rises (Net sea level rise (mm per year) relative to 1990)

	1990 to 2025	2025 to 2055	2055 to 2085	2085 to 2115
East of England, east midlands, London, south-east England (south of Flamborough Head)	4.0	8.5	12.0	15.0
South-west England	3.5	8.0	11.5	14.5
North-west England, north-east England (north of Flamborough Head)	2.5	7.0	10.0	13.0

document is out of date

Table 2: Recommended national precautionary sensitivity ranges for peak rainfall intensity, peak river flow, offshore wind speed and wave height

Parameter	1990 to 2025	2025 to 2055	2055 to 2085	2085 to 2115
Peak rainfall intensity	+5%	+10%	+20%	+30%
Peak river flow	+10%	+20%		
Offshore wind speed	+5%		+10%	
Extreme wave height	+5%		+10%	

s been withdrawn (19

Revised 2016 EA Guidance

Table 1 peak river flow allowances by river basin district (use 1961 to 1990 baseline)

River basin district	Allowance category	Total potential change anticipated for '2020s' (2015 to 39)	Total potential change anticipated for '2050s' (2040 to 2069)	Total potential change anticipated for '2080s' (2070 to 2115)
Anglian	Upper end	25%	35%	65%
	Higher central	15%	20%	35%
	Central	10%	15%	25%

For more vulnerable development in flood zone 3(a) the higher central and upper end should be used to assess the range of allowances.

Table 2 peak rainfall intensity allowance in small and urban catchments (use 1961 to 1990 baseline)

Applies across all of England	Total potential change anticipated for 2010 to 2039	Total potential change anticipated for 2040 to 2059	Total potential change anticipated for 2060 to 2115
Upper end	10%	20%	40%
Central	5%	10%	20%

Table 3 sea level allowance for each epoch in millimetres (mm) per year with cumulative sea level rise for each epoch in brackets (use 1990 baseline)

Area of England	1990 to 2025	2026 to 2050	2051 to 2080	2081 to 2115	Cumulative rise 1990 to 2115 / metres (m)
East, east midlands, London, south east	4 (140 mm)	8.5 (212.5 mm)	12 (360 mm)	15 (525 mm)	1.24 m

Table 4 offshore wind speed and extreme wave height allowance (use 1990 baseline)

Applies around all the English coast	1990 to 2050	2051 to 2115
Offshore wind speed allowance	+5%	+10%
Offshore wind speed sensitivity test	+10%	+10%
Extreme wave height allowance	+5%	+10%
Extreme wave height sensitivity test	+10%	+10%

Effects on Predictions of Flood Risk in FRA

The FRA has identified the main source of flooding where the new climate change recommendations could affect the predictions of flood levels in 2115 at the development site is flooding from the tidal River Nene

The contingency allowance in metres for the years 2055 and 2115 using 1990 as a baseline in the SFRA compared with the guidelines is as follows

Year	SFRA	2013 guidance	Revised 2016 guidance
2055	0.33	0.395	0.412
2115	1.14	1.205	1.24

Therefore it can be seen that the revised guidance increases the maximum allowance for sea rise in 2115 by 100mm. This will not have the effect of increasing the predicted flood level at the site in a 1 in 200 year breach event in 2115 by the maximum of 100mm, but it will probably be only between 10mm and 50mm. It is unlikely that this increase will significantly change the maps of flood risk at present issued by the Environment Agency.

Flooding from IDB drainage system

As the development is in flood zone 3 and is classed as more vulnerable, the advice from the Environment Agency is that the higher central climate change allowance, which is 35%, should be considered. After considering the effects of this increase the upper end allowance, which is 65%, should be considered to assess the effect of this.

IDB's have been using an allowance of 20% for climate change over the past few years in their assessments and modelling of their systems. Generally IDB's are happy that their systems provide a 1 in 100 year standard to most urban areas at the present time.

North Level IDB, and all IDB's, are aware that climate change will affect the operations of pumping stations, sluices and drainage channels. Pumping stations and sluices only have a 30 year life and will need to be refurbished or rebuilt within this timespan. It is assumed that North Level IDB will continue to review the modelling they have already carried out and when the Board consider these refurbishments adequate arrangements will be made to incorporate the latest climate change projections in order that the Board continues to provide the same standard of service as the present day.

Therefore it is considered that the mitigation proposed for the development, with the recommendation that the ground floor level of the proposed annex should be minimum level of 2.60m OD, is satisfactory.