

Online Comment

Application H21-1136-23
Location Land north of 29 Station Road Tydd Gote Wisbech PE13 5QA
Proposal Proposed holiday lodges and yoga building

Name Stuart Greenfield
Address Building Control - South Holland District Council

Date Submitted 04-02-24
For/Against Comments

The access road should have provision for supporting an 18 tonne Fire Appliance to within 45m of every point of the footprint of every building and have a minimum width of 3.7m.