

Online Comment

Application H22-0797-17
Location Land at Small Drove Weston Spalding
Proposal Details of contaminated land, external materials, landscaping plans, boundary treatment, public open space management plan and bat and bird boxes. (Conditions 3, 4, 5, 6, 7 and 16 of H22-0970-15) allowed on appeal.

Name J Reith
Address Environmental Health Technician Safety and Environment

Date Submitted 04-10-17
For/Against Comments

The Phase I & II Geo-Environmental Assessment(Ref. UK15.1906 dated 5 August 15) by EPS satisfies the contaminated land condition. I would like to draw the applicant's attention to the asbestos containing materials on site and that they should be removed by a specialist contractor.