Online Comment

Application	H22-0923-17
Location	Site Adj to 30 Austendyke Road Weston Hills Spalding PE12 6BX
Proposal	Details of Closure Report (Condition 8 (iii) of H22-1300-16)

Name	Noise and Contaminated Land
Address	Environmental Health Technician Safety and Environment
Date Submitted	25-10-17
For/Against	Comments

The Validation Report - First Stage (Ref 973/4008/P dated August 2017) by Humberside Materials Laboratory details that the underground storage tank has been removed as per the method statement. Other validation is required on site, so therefore part 4 of the condition cannot be discharged until all of the evidence has been submitted.