Online Comment

Application	H22-1300-16
Location	Site adjacent: 30 Austendyke Road Weston Hills Spalding PE12 6BX
Proposal	Proposed 4 detached houses

Name	J Reith
Address	Environmental Health Technician Safety and Environment

Date Submitted	27-01-17
For/Against	Comments

I have read the Site Investigation Report by Humberside Materials Laboratory Ltd. Ref 973/4008/P dated August 2016. There are areas of the site that require further investigation with regards to contamination. In particular an asbestos survey needs to be carried out and the underground fuel storage tanks require removal and further testing of the base and sides. I require a remediation method statement prior to any works taking place and therefore request parts 2 - 4 of the contaminated land condition for this application.