Online Comment

Application	H23-0057-17
Location	Yew Lodge Farm Gull Bank Whaplode Drove PE11 0SS
Proposal	Erect new steel framed building to form new potato cold store and unload/loading area.

Name	Steve Branson
Address	Environmental Health Technician Safety and Environment
Date Submitted	15-02-17
For/Against	Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background level by more than 5dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.