



INDICATIVE ROOF PLAN (SOUTH AISLE)

AS PROPOSED

- New TCS Batten Roll Seams are shown at max. 550mm centres
Existing South Aisle Lead Sheet Roof is approx. 4.5° Pitch
w1-8 = Clerestorey Windows
o1-6 = Leaded Outlet Spouts and Sumps
- All Existing Lead Roof Coverings, Gutter Linings and Flashings etc. to be carefully removed
Any significant undulations in the Timber Substrate to be levelled-up as necessary
Any exposed defective Timber Sarking Boards to be replaced on a Like for Like basis
- Install New TCS Roof Covering to follow the Existing Layout and Falls etc.
- Existing Gutter Linings and Flashings to be replaced in TCS - Subject to confirmation on Site
New Gutter Linings and Flashings to be pointed up in Lime Mortar or Burnt Sand Mastic Flashings
- Existing Clerestorey Cill Weatherings and Cover Flashings to be replaced in Code 5 Lead
Precise detail to be agreed following Site Inspection
- All Outlet Chutes to be replaced to Existing Patterns in min. Code 7 Lead
- All Masonry affected by the works to be re-pointed in Lime Mortar, and repaired/replaced where necessary. Check integrity of all parapet copings
- New Roof to be un-insulated and un-vented, as Existing

REFER TO FULL CONTRACT SPECIFICATION FOR DETAILED WORKS INFORMATION

DRAWING IS BASED ON SITE MEASUREMENTS, BUT IS FOR GUIDANCE ONLY,
AND WILL NOT BE 100% DIMENSIONALLY NOR GEOMETRICALLY ACCURATE.
ANY CRITICAL DIMENSIONS OR LEVELS MUST BE TAKEN ON SITE



REVISION: WITH GENERAL SUMMARY OF CHANGES
A January'25 - Added further General Notes

TO BE READ IN CONJUNCTION WITH ARCHITECT'S SPECIFICATION AND ANY OTHER DRAWINGS
ALSO TO BE READ IN CONJUNCTION WITH LOCAL AUTHORITY PLANNING PERMISSION AND
BUILDING REGULATIONS APPROVAL AND ANY OTHER CONSENTS
ALSO TO BE READ IN CONJUNCTION WITH ANY ENGINEERS STRUCTURAL CALCULATIONS AND DETAILS
ALL EXTERNAL MATERIALS & FINISHES TO MATCH THOSE EXISTING, UNLESS OTHERWISE AGREED
ALL DIMENSIONS, LEVELS, STRUCTURES ETC. TO BE CHECKED AND AGREED ON SITE
DO NOT SCALE FROM DRAWINGS

| | | | |
|---|---|---|----------------|
| ROGER WRIGHT - ARCHITECT Camden Villa, 90 Monks Road, Lincoln. LN2 5HU. Tel. (01522) 527758 Email. rwarchitect@ntlworld.com | CLIENT : The PCC & Churchwardens of All Saints Church, Kirkgate, Whaplode, Lincolnshire | DWG NO. 03 | REV. A |
| | | SCALE : 1:50 Approx. | PAPER SIZE: A1 |
| | PROJECT : Renewal of South Aisle Roof Covering etc. | DRAWN : RTW | DATE: Sept.'21 |
| | | TITLE : ROOF PLAN - As Proposed (TCS) with Notes | |

ROGER WRIGHT - ARCHITECT